



Manufacturer: <u>Illume Lighting</u>
Model Number Tested: <u>I-DSPN4SN</u>

Other Model Numbers: <u>I-DSPN4WH, I-DSPN4xx,</u>

Manufacturer's Description

Type of device: <u>LED 9 W Downlight</u> Control Type: <u>Forward and Reverse Phase Control</u>

Operating voltage: 120V Dimming Range: Not Specified Input Power 9.0 W Output Power: Not Specified Input Current: Not Specified Lumen Output: 580 Im Input Frequency: 60 Hz/50 Hz Type/Shape: Downlight Base Type: Not Specified

Lutron Test Results

 Date Tested:
 29-Aug-16

 Test Voltage:
 120 V

Test Notes: Performance verified with up to 16 fixtures per control. Test results valid only at 120 V and 60 Hz.

Lutron Recommended Products

Lutron products not in this list can be considered to be not recommended, based on our testing.

Product	Model Number	Control Type ⁽¹⁾	Fixtures per Dimmer ⁽²⁾ Min-Max	Measured Dimming Range ⁽³⁾ (Software Trim Settings)		Perceived Low End ⁽⁴⁾	Comments
	Wallbox Dimmers						
Diva/	C·L wall-mount	FP	1 - 16	15%	99%	38%	
Skylark/	dimmers (T8,						
Skylark Contour/	T9)*						
Ariadni/							
Toggler/ Lumea							
Maestro	MACL-153M (_)*	FP	1 - 16	16%	96%	40%	
Maestro Wireless	MRF2-6ELV	RP	1 - 16	20%	99%	44%	Load type not selectable.
Maestro Sensor	MSCL-OP153M (T2)*/ MSCL-VP153M (T2)*	FP	1 - 16	16%	96%	40%	
Maestro Wireless	MRF2-6CL (M6)*	FP	1 - 16	15%	97%	39%	
Grafik T	Phase Selectable GT- 5NEM/ GTJ- 5NEM	RP	1 - 27	19%	99%	44%	
Commercial Systems							
Stanza	SZ-6ND	FP	1 - 6	12% (6)	100% (99)	35%	
Panel Module	HW/LP-RPM-4A- 120	RP	1 - 77	18% (18)	100% (82)	42%	Rating is per channel; total per module is 123.
Panel Module	HW/LP-RPM-4U- 120	FP	1 - 27	12% (16)	100% (82)	34%	Rating is per channel; total per module is 27.
Grafik QS/ Wallbox Power Module	Grafik Eye QS Main Unit Family/ LQRJ-WPM-6P	FP	1 - 27	16% (23)	100% (81)	41%	Rating is per output; total quantity per Main Unit is 67.
Panel Module	GP (Harrier) Card	FP	1 - 27	16% (21)	98% (82)	41%	Rating is per output. Use load type 2-1.

Grafik Eye 3000/ HomeWorks	Grafik Eye 3000 Family/	FP	1 - 27	16% (23)	100% (81)	41%	Rating is per output; total quantity per Main Unit is
	HWI-WPM-6D- 120						40/50/67/67 for 2/3/4/6-Zone units, respectively.
HomeWorksQS/ myRoom	LQSE-4A1-D/ MQSE-4A1-D/ MQSE-3A1/ MQSE-2A1-D, 120V, RP	RP	1 - 6	11% (10)	100% (99)	34%	Rating is per output; total quantity per Main Unit is 24.
Grafik T	Phase Selectable GT- 5NEM/ GTJ- 5NEM	RP	1 - 27	19%	99%	44%	
Residential Systems							
RadioRA 2	RRD-6NA	RP	1 - 16	20%	99%	44%	
HomeWorks QS	HQRD-6NA	RP	1 - 16	20%	99%	44%	
HomeWorks	HxD-6ND	FP	1 - 6	12% (6)	100% (99)	35%	
Panel Module	HW/LP-RPM-4A- 120	RP	1 - 77	18% (18)	100% (82)	42%	Rating is per channel; total per module is 123.
Panel Module	HW/LP-RPM-4U- 120	FP	1 - 27	12% (16)	100% (82)	34%	Rating is per channel; total per module is 27.
Grafik QS/ Wallbox Power Module	Grafik Eye QS Main Unit Family/ LQRJ-WPM-6P	FP	1 - 27	16% (23)	100% (81)	41%	Rating is per output; total quantity per Main Unit is 67.
Panel Module	GP (Harrier) Card	FP	1 - 27	16% (21)	98% (82)	41%	Rating is per output. Use load type 2-1.
Grafik Eye 3000/ HomeWorks	Grafik Eye 3000 Family/ HWI-WPM-6D- 120	FP	1 - 27	16% (23)	100% (81)	41%	Rating is per output; total quantity per Main Unit is 40/50/67/67 for 2/3/4/6-Zone units, respectively.
RadioRA 2	RRD-6CL (R3)*	FP	1 - 16	15%	97%	39%	
HomeWorks QS	HQRD-6CL (H2)*/ HQRA-6CL (H2)*	FP	1 - 16	15%	97%	39%	
RadioRA 2	Hybrid Keypad C.L RRD- HN6BRL	FP	1 - 11	12% (20)	99% (99)	35%	Installation with a neutral wire is required.
HomeWorks QS	Hybrid Keypad C.L HQRD- HN6BRL	FP	1 - 11	12% (20)	99% (99)	35%	Installation with a neutral wire is required.
HomeWorksQS/ myRoom	LQSE-4A1-D/ MQSE-4A1-D/ MQSE-3A1/ MQSE-2A1-D, 120V, RP	RP	1 - 6	11% (10)	100% (99)	34%	Rating is per output; total quantity per Main Unit is 24.
Grafik T	Phase Selectable GT- 5NEM/ GTJ- 5NEM	RP	1 - 27	19%	99%	44%	
Interfaces (5)							
	PHPM-PA with Grafik Eye	RP	1 - 77	18% (22)	98% (77)	42%	
	QS Main Unit PHPM-WBX with 3-wire fluorescent control	RP	1 - 77	18%	98%	42%	
Notes:	* Identical model numicontact technical sup (1) Control types of FF (2) Maximum Fixtures (3) Values are based of Values are set to op low end, and trimm (4) Perceived light leve	port for add P and RP re per Dimme on light outp ptimize perf ing out insta el percentag	litional information. present Forward P r value represents out using the specif ormance, such as ability. Software tri ge is the square roo	hase and Reverse F the maximum safe li ied dimming control, reducing dead trave m values are indicat ot of the measured li	Phase, respectively oading of the control, and may not be an I, ensuring that fixtured in parentheses wight level percentage	See product li indication of the sturn on at lehen applicable, per IESNA Li	ne fixture's full rated capability. ow end, reducing turn-on time at e.

Test Comments: Performance verified with up to 16 fixtures per control.

For any questions on this report, please contact the Lutron LED Center of Excellence at 877-DIM-LED8 or leds@lutron.com.

This information was posted with the consent and cooperation of the device manufacturer. Please be aware that device manufacturers may modify their product at any time, without notice to Lutron, and therefore Lutron cannot ensure future compatibility. For more detailed and up to date fixture specifications, performance and/or any related recall information, visit the manufacturer's website. The latest Lutron test results can always be found at www.lutron.com/LEDtool.