



295 Alliance Road
Milton, Ontario
L9T 4W8
Tel: 905-876-0707
1-800-567-9791
Fax: 905-876-0695

The Glycol People

Geo Loop Leak Seal & Conditioner Instructions:

SHAKE WELL BEFORE USING

CAUTION: Not to be used in systems with strainers or transducers unless they can be isolated from the product.

Directions for use:

For preventative maintenance of vertical or horizontal ground loops, mix one 8 oz. bottle and add to geothermal loop field while purging the system or by introducing thru P/T port if the system is up and running and reflushing is not necessary. Add 8 oz. of product for each five tons of ground loop, six thru ten tons-16 ozs, etc. For troublesome loops where water loss may be evident account of age of equipment, poor connections, fusion joints, sweated joints, old pvc glue joints, or any other condition causing a system to loose fluid, after first repairing all the obvious items that can be found, add the above mentioned amounts to ground loop as described above. If the water loss is expected to be underground and the result of a bad fusion, add double the amount, keep the loop pressured up, and give ground loop sufficient time to repair itself.

Mixing Directions:

Shake contents well before adding to water. Use an empty container two or three times the size of intended amount of conditioner to be added. Fill empty container less than half full of water and then pour in conditioner and shake until well mixed. Incorporate into loop field by one of the above mentioned methods.

PRECAUTIONS:

KEEP OUT OF REACH OF CHILDREN. CAUSES SEVERE EYE AND SKIN IRRITATION.

DO NOT GET IN EYES, ON SKIN, OR ON CLOTHING.

HARMFUL OR FATAL IF SWALLOWED.

AVOID CONTAMINATION OF FOOD.

RINSE EMPTY CONTAINER THOROUGHLY WITH WATER AND DISCARD.

HOOD CHEMICAL does not assume any responsibility for the performance of this product.