

ORNL-6527

Energy Division

Guide for Estimating Differences in Building Heating and Cooling Energy Due to Changes in Solar Reflectance of a Low-Sloped Roof

E. I. Griggs
T. R. Sharp
J. M. MacDonald

*Part of the
National Program for
Building Thermal Envelope Systems and Materials*

Date Published – August 1989

Sponsored by

Office Of Buildings and Community Systems

Prepared by the
OAK RIDGE NATIONAL LABORATORY
Oak Ridge, Tennessee 37831
operated by
MARTIN MARIETTA ENERGY SYSTEMS, INC.
for the
U.S. DEPARTMENT OF ENERGY
under contract No. DE-AC05-84OR21400

Summary

Guide for Estimating Differences in Building Heating and Cooling Energy Due to Changes in Solar Reflectance of a Low-Sloped Roof

An increase in roof solar reflectance results in a saving of building cooling energy and an increase in building heating energy. This guide provides data and calculation procedures for estimating the change in HVAC energy and resultant cost savings associated with changing the solar reflectance of low-sloped roofs. A brief consideration of exterior surface mass shows that the annual energy and cost savings are small compared to the effect of changing roof solar reflectance.

This guide can be used to perform different types of savings estimates related to changing roof solar reflectance, including: savings for a change to a higher roof solar reflectance, comparison of savings for two different products, and estimating changes in savings due to degradation of reflectance



In most instances, the cooling cost savings associated with a change to a white roof surface (one with higher solar reflectance) exceed the heating cost penalty. This should not be construed as a blanket endorsement of high solar reflectance roofs. Many factors beyond the scope of this guide should be considered. Roof maintenance costs, roof life, dirt accumulation, and different material costs are examples.

An increase in solar reflectance will decrease the peak daytime temperatures of a roof. Black surfaces routinely exceed 160EF on summer days. Under similar conditions flat white surfaces reach 135EF and glazed white surfaces seldom go above 120EF.



The important parameters to consider when evaluating the total energy impact of a change in roof solar reflectance are: insulation R-value, climate, solar radiation, building use and type, and the efficiencies of heating and cooling equipment. For example, **the fuel cost savings for a change to a white roof surface decrease sharply with increases in the amount of roof insulation.**

Roof surface aging generally decreases the solar reflectance of a white coating or membrane and increases the solar reflectance of an originally black one. Thus, the decreased effectiveness of an aged white surface compared to a black surface is underestimated if the simultaneous aging of the black surface is not taken into account.

Adding mass—for example, pavers or ballast—to the surface of a roof lowers the peak daytime membrane temperatures 10–20EF compared to a bare black membrane.



In the summer, high solar reflectance helps keep the heat from the sun away from the building during the day (a), and high infrared emittance helps radiate heat away from the roof both day and night (b).



In the winter, low solar reflectance helps to trap heat from the sun during the day (a), and low infrared emittance reduces heat radiated from the roof both day and night (b).

Contents

	Page
SUMMARY	2
CONTENTS	4
LIST OF FIGURES	5
PURPOSE	6
LIMITATIONS	6
1. ROOF REFLECTANCE AND ITS SIGNIFICANCE	8
2. FACTORS INFLUENCING SURFACE TEMPERATURES OF LOW-SLOPED ROOFS	10
Roof Surface Color and Texture	
Solar Intensity	
Sky Conditions	
Roof Insulation	
Roof Surface Infrared Emittance	
Roof Surface Mass	
3. FACTORS THAT AFFECT THE ENERGY SAVINGS AVAILABLE FROM CHANGING ROOF REFLECTANCE	14
R-Value of Roof Insulation	
Climate	
Building Type and Use	
Roof Surface Property Changes	
4. EVALUATING ENERGY COST SAVINGS FROM A CHANGE IN ROOF REFLECTANCE	17
Data Requirements	
Completing the Savings Worksheet	
EXAMPLE: Roof Reflectance Change for an Office Building.	
EXAMPLE: Roof Reflectance Change for Industrial and Retail Buildings	
Interpreting Results	
BIBLIOGRAPHY	27
APPENDIX A - WEATHER DATA	30
APPENDIX B - ENERGY COSTS FOR SPECIFIC CITIES (1985)	34
APPENDIX C - REFERENCE REFLECTANCES	36
APPENDIX D - COOLING AND HEATING FACTORS	38
APPENDIX E - ENERGY SAVINGS AVAILABLE FROM CHANGING ROOF SURFACE MASS	48
APPENDIX F - NOTES ON THE DEVELOPMENT OF THIS GUIDE	50

List of Figures

	Page
1 Distribution of hourly temperatures for dark and light roofs	10
2 Comparison of surface temperatures for white and black roof membranes, July 15–21, 1986	11
3 Comparison of solar intensity	11
4 Effect of wind	12
5 Effect of R-value	12
6 Effect of infrared emittance	13
7 Effect of surface mass	13
8 Effect of R-value on net energy savings for an increase of 0.5 in roof reflectance	14
9 Climate effect on energy savings for a change of 0.5 in roof reflectance	15
10 Comparison of relative roof area	15
11 Effects of weathering	16
E-1 Effect of surface mass on heat gain	48
E-2 Effect of surface mass on heat loss	48
E-3 Effect of surface mass on cooling energy (Phoenix, AZ)	49
E-4 Effect of surface mass on heating energy (Minot, N. D.)	49

Guide for Estimating Differences in Building Heating and Cooling Energy Due to Changes in Solar Reflectance of a Low-Sloped Roof

PURPOSE

This guidebook describes a procedure that can be used to estimate changes in heating and cooling costs and the net energy cost difference for a building as a result of changing roof “color,” or more technically roof solar reflectance.

The cost of heating and cooling a building is affected by roof color. A higher roof solar reflectance reduces the solar energy absorbed by the roof and therefore usually provides a reduction in the cost of air conditioning, while causing heating costs to increase. If the difference between reduced cooling costs and increased heating costs is significant, it can affect the choice of membrane for a new roof or a re-roofed building. This guidebook helps the user estimate this energy cost difference for his particular roof. It also describes how various factors influence potential energy savings and actual roof surface temperatures for different solar reflectances.

The guidebook is intended to be used by building owners, roofing contractors, or other interested individuals who wish to evaluate the energy cost impacts of different roof solar reflectances.

LIMITATIONS

The principal purpose of this document is to answer the question:

What is the net impact of increasing the solar reflectance of a roof on the energy use of a particular building?

It is intended to shed quantitative insight and aid in decision making; it is not intended to provide answers with scientific precision. The heating and cooling factors provided in this document are based on computer simulations of annual building energy use with typical meteorological year weather data as input. These simulations kept some values as constants which would normally vary throughout the year as the weather changes. Also, some factors that would affect energy use were not included so that the procedure presented here could be kept simple. Accordingly, the following limitations are noted:

1. The roof's reflectance of solar energy throughout the year is characterized by a single value of solar reflectance and the reflection of sunlight is the same from all parts of the roof for all seasons.
2. The roof is dry. Any effect due to the presence of accumulated water as a liquid, frost, or snow is not treated.

3. The roof is totally exposed to the sky. No external shading such as trees or other structures was considered.

4. The infrared emittance is assumed to be the same for all surfaces.

5. Reference to a roof in this document indicates a near-flat roof. The construction consists of a metal deck, insulation, and an exterior waterproof covering. Pitched roofs and roofs over attic spaces are not covered. Cases presented do include that of a suspended ceiling below the roof assembly.

6. Changing roof reflectance can affect the energy use of a building and can also affect the size of heating or cooling equipment needed. A change in energy use or a change in equipment size can possibly lead to cost savings. Cost savings from a change in energy use could benefit both existing buildings and new building designs, while a cost savings from a change in equipment size would typically benefit new building designs. The savings evaluated here pertain only to the savings from changes in heating and cooling energy use, and potential equipment cost benefits would have to be evaluated separately.

A multitude of interrelated factors affect building energy use. Definition of periods of heating and cooling are determined by coupling of these factors. Correlations of computed results for selected conditions, such as those presented, are useful to show trends and help quantify effects; however, they cannot and should not be interpreted as exactly matching every unique setting.

This document is intended to provide a straightforward aid to users in estimating the energy conservation potential offered by use of reflective roofs. The data provided are based on computations using a widely accepted simulation code (DOE-2.1B) which has been corroborated by some experimental measurements. However, many considerations emerge when applying the technology of higher reflectance roof surfaces, and the procedure presented in this document is not intended to imply that analysis of changes in energy use from application of this technology is simple.

Section 1

ROOF REFLECTANCE AND ITS SIGNIFICANCE


It is common experience that some sunlit objects become hotter than others. This is true for roofs. It is possible that one could comfortably touch one roof yet find the touch of another most uncomfortable under otherwise identical climatic conditions. Just how hot a roof gets depends on many factors and a major one is the roof surface solar reflectance.

Some roofs reflect the sun's rays better than others and hence do not get as hot. Highly reflective surfaces are often thought of as being "white." Dark-colored roofs, which generally have low reflectances, are typically much hotter than white roofs during daytime hours and can easily reach temperatures of 165°F during clear, sunny conditions.


Roof solar reflectance affects daytime roof surface temperature and hence impacts building heating and cooling costs. The biggest temperature effect occurs during the day, when the sun heats the roof and increases the heat flow into the building. Heat flow into a building is an asset when building heating is needed and a liability when building cooling is needed. Hence, roof reflectance can effect energy savings by impacting heating and cooling energy requirements. In terms of energy needs, a white (highly-reflective) roof is preferred during sunlit hours when building cooling is needed and a black one is preferred during sunlit hours when building heating is needed. Thus, there is a counteracting influence of roof solar reflectance (color) on a building's heating and cooling energy requirements in many parts of the country.

The prevalence of asphaltic materials in built-up roofs means that many existing low-sloped roofs are black and have a low solar reflectance. Aggregate surfacing can increase the roof's reflectance. Roofs are also constructed using painted and unpainted metal roofs. Single-ply membranes are becoming more commonplace as a roof covering. With both painted roofs and membranes, a range of colors is available. Since low-sloped roofs constitute a significant portion of the overall thermal envelope of low-rise buildings and with the many available options for roof color, changing roof reflectance is now a viable option for reducing the energy costs of many buildings.

The most notable examples of reduced energy costs come from replacing black roofs by white roofs on buildings with high air conditioning loads. The prospects of reduced energy costs, along with the lower surface temperatures of white membranes, have been instrumental in creating a strong demand for high reflectance, white membranes. In general, white systems are more expensive. The cost differential is unique for a given situation and must be known by the decision maker. Thus, it is necessary to also provide a decision maker with a good estimate of the cost savings that will result for different reflectance options.



DARKER ROOFS
MEAN HIGHER
SUMMER ROOF
TEMPERATURES



IN SUMMER, A DARKER ROOF
CAN IMPOSE A HIGHER COOLING LOAD
ON BUILDING COOLING SYSTEMS

Section 2

FACTORS INFLUENCING SURFACE TEMPERATURES OF LOW-SLOPED ROOFS

The solar reflectance of a roof membrane plays a key role in determining the daytime temperature of a roof. On a bright summer day the temperature of a black membrane can easily exceed 160EF while it can be as low as 100EF for a similar roof with a smooth white membrane under identical conditions. While little direct evidence exists to suggest that roofs with high solar reflectance and resultant lower daytime temperature peaks have a longer life because of the lower temperatures, it is generally felt that higher temperatures will accelerate deterioration and should be avoided.

Computers can accurately predict roof surface temperatures when the characteristics of the roof and the environmental conditions are known. While this degree of detail is not usually required, it is worthwhile to describe the factors that most significantly affect roof surface temperature. Those discussed are:

- Roof surface color and texture
- Solar intensity
- Sky conditions
- Roof insulation
- Roof surface infrared emittance
- Roof surface mass

ROOF SURFACE COLOR AND TEXTURE




Figure 1 – Distribution of hourly temperatures for dark and light roofs.

At a site in east Tennessee, one half of a test panel was covered with a black EPDM membrane and the other half with a white EPDM membrane. The panel was insulated to R-7.5. The figure shows that, for 7824 hourly measurements within the period of March 1986 to March 1987, the white membrane had more hours at moderate temperatures and no hours at 140–190EF.

It is well known that a dark colored membrane absorbs more solar energy than a light colored one. One property that characterizes this effect is the “solar reflectance.” If incident solar energy is totally absorbed the surface has a reflectance of zero and if it is totally reflected it has a reflectance of one. All materials have values somewhere between zero and one. The solar reflectance of several common materials is given in Appendix B. Color is a fairly good indicator of solar reflectance. Dark surfaces have low solar reflectance and light surfaces high solar reflectance. Texture also is significant in determining the solar reflectance of a surface. Generally, light reflecting from a rough surface has a better chance of striking the surface a

second time—and therefore being absorbed—than light from a smooth surface. Thus, other things being equal, a rough surface will have a lower solar reflectance and therefore will be warmer in sunlight than a smooth surface. Aging, either from chemical changes in a membrane or from dirt or contaminants in the air, usually tends to drive roof surfaces toward the color gray. Thus, initially white roofs with high solar reflectance tend toward lower reflectances and higher temperatures while initially black roofs with low solar reflectance tend toward a higher reflectance and lower temperatures.

SOLAR INTENSITY

The sun is the primary energy source for a roof surface that is heated above the ambient air temperature. The amount of useful sunlight varies with time of year, and with location and local weather peculiarities. In general, southern sites and mountainous regions have more useful sun and therefore higher roof temperatures. In many instances, however, local high cloud cover or high humidity absorb solar radiation and significantly reduce the amount of useful sunlight. For example, February useful sunlight in New Orleans, LA, on the Gulf coast is about the same as in Laramie, WY, and in the summer it is actually about 30 percent less. This is due to the high water vapor content of the air along the Gulf Coast compared to the clear mountain sky of the Rocky Mountain area.




Figure 2 – Comparison of surface temperatures for white and black roof membranes, July 15–21, 1986.
The difference between the peak temperatures of white and black membranes during typical hot summer conditions is pronounced, as shown above. These temperature measurements are from the data summarized in Fig. 1.




Figure 3 – Comparison of solar intensity.
The data on average solar energy for each month for the 4 cities show that differences during the summer are not as different as might be expected for climates that are noticeably different. Lower winter solar energy in some climates means that increases in heating energy use for buildings with white membranes would be smaller.

SKY CONDITIONS (Wind, Rain, Clouds)

During a warm summer day the sun can cause the temperature on a dark roof to reach 160EF to 180EF when the air temperature is only 80EF to 90EF. Since the roof is not very massive and cannot store much heat, events such as a quick shower, a cool wind, or even a large cloud can lead to reductions in roof temperatures.




Figure 4 – Effect of wind.

The effect of wind speed on maximum membrane temperature is shown in this figure for a black roof. These results were obtained by simulation using weather conditions taken from the same data shown in Fig. 1 for a week in May 1986. The maximum air temperatures during this week were 80–85EF, and the solar energy peaks were 300–320 Btu/hr-ft².




Figure 5 – Effect of R-value.

Using the same data as shown in Fig. 4, the effect of changes in R-value on maximum membrane temperature for a black membrane were modeled and are shown for two values of reflectance.

Exact calculation of the effects of these rapid changes on particular roofs are difficult to carry out because they are such irregular phenomena. The chart to the left shows the approximate effect of wind. For a black built-up roof the maximum peak temperature during a week of hot summer weather can be 5–10EF lower when the wind increases from 0 to 10 mph, and 25–30EF lower in a 20 mph wind. Note that for a high-solar-reflectance white roof, the initial difference between surface temperature and air temperature is reduced. Therefore, the magnitude of rapid temperature changes caused by sky conditions will be much less severe for a white roof than for a black roof.

ROOF INSULATION

Other things being equal a roof with more insulation will have less heat carried from the roof into a building on a sunny day than a roof with less insulation and this should cause it to have a higher surface temperature. The magnitude of the surface temperature depends upon the amount of insulation. As can be seen in Fig. 5, after even a small amount of insulation has been added to a roof, further increases have little effect on the temperature. The reason is that the surface temperature depends upon the net exchange of energy between the roof surface and the outdoor and indoor environments. As the amount of roof insulation is increased, the surface becomes more shielded from energy exchange with the indoor environment (conditioned space), and the surface temperature is controlled by external influences such as solar energy, wind, rain, and outdoor air temperature. Note, however, that insulation increases still have an impact on fuel bills. That is, if the insulation is doubled, the peak daytime surface temperature may only decrease a few degrees, but the heat loss or gain (and costs for resulting heating or cooling energy) will still be approximately halved.

ROOF SURFACE INFRARED EMITTANCE

A roof surface radiates infrared energy to the sky and the surroundings. During the day incident solar energy more than makes up for this infrared radiation, and a roof can be heated well above the ambient air temperature. During the evening, however, with no solar radiation, the loss of radiant energy to the sky can cool a roof below the ambient air temperature. Evening surface temperatures 20°F below air temperatures on clear, low humidity nights are common for well insulated roofs. While radiant cooling of a roof will increase the nighttime heat loss, the effect is not included in the calculations of this manual because most roofing materials have about the same infrared radiation properties even though their solar radiation properties can be quite different.

ROOF SURFACE MASS

When mass is added to the surface of a roof, such as with paver blocks or gravel ballast, it acts as a thermal flywheel. Its effect on roof temperatures is to smooth out the variations from day to night. This results in lower peak temperatures than would be found with a bare roof. Figure 7 shows peak membrane temperatures calculated for roofs with various amounts of surface mass. This figure shows that peak membrane temperature is reduced as the amount of surface mass increases and added surface mass has a substantially larger effect than the effect of changes in roof insulation level.




Figure 6 – Effect of infrared emittance.

The effect of infrared emittance at night can be seen in this figure. Solar energy heats the roof to significant temperature differences between the roof surface and ambient air during the day, but the temperature difference is often negative at night—indicating that the roof is cooled below the air temperature. The night cooling effect is shown to be nearly identical for white and gray roofs. The data are for the week of August 2, 1988.




Figure 7 – Effect of surface mass.

Using the same data as in Figs. 4 and 5, the effect of surface mass on peak membrane temperature during a week was modeled, and the results are shown here.

Section 3

FACTORS THAT AFFECT THE ENERGY SAVINGS AVAILABLE FROM CHANGING ROOF SOLAR REFLECTANCE

The energy savings achievable by changing roof reflectance is predominantly influenced by:

- R-value of roof insulation
- Climate
- Building type and use
- Roof surface property changes

Each of these factors have varying degrees of influence on the potential for energy cost reductions resulting from reflectance change. The effect of surface mass (e.g., ballast) is discussed in Appendix E.

R-VALUE OF ROOF INSULATION

The amount of roof insulation is a major factor influencing the energy savings potentially available from a change in roof reflectance. If a roof is well insulated, little heat is transported between the roof surface and the building interior. Thus, although a change in roof reflectance changes the roof surface temperature, the building energy use will experience little impact.




Figure 8 – Effect of R-value on net energy savings for an increase of 0.5 in roof reflectance.

The effect of R-value on the net energy savings (cooling savings minus heating penalty) due to changing roof reflectance is dramatic. These impacts are shown here for four diverse climates.

The influence of insulation on the savings from changes in roof reflectance is shown in Fig. 8. Reflectance change will reduce energy costs the most for lower roof insulation levels. In cooling dominated climates, reductions in energy savings can also be significant for higher levels of roof insulation.

CLIMATE

Climate has a strong influence on both building energy use and on the resulting energy savings available from changing roof reflectance. Since climate often dictates the size of the energy bill, it also affects the size of potential savings from reflectance change. Outdoor temperatures, solar radiation, and wind speed are significant climate factors.

Increasing roof reflectance results in a reduced summer cooling load and an increased winter heating load. Since there is a tradeoff, an increase in roof reflectance is typically most beneficial in hot climates where cooling load dominates most of the the year. Climate effects on energy savings from reflectance change is illustrated in Fig. 9. This figure shows that potential savings are greatest in cooling season dominated climates. For the building configurations and climates examined for this work, the reduction in cooling load always exceeded the increase in heating load, but the distinction was small in nothern climates. This trend does not imply that white is always better than black, because the benefits of savings must be compared to the relative costs of the white and black materials.




Figure 9 – Climate effect on energy savings for a change of 0.5 in roof reflectance.

These results are for a roof R-value of 4.

BUILDING TYPE AND USE

Different buildings use differing amounts of energy and, therefore, will benefit differently from roof reflectance change. Energy intensive buildings such as office or retail buildings often have large internal loads which extend the buildings cooling season. These building types could benefit even more from increasing roof reflectance since energy savings are most significant in cooling dominated climates.

In high-rise buildings, the roof makes up a small portion of the above-ground building shell. Although savings can justify a reflectance change for these buildings, the magnitude of savings will be small in comparison to the buildings total energy bill. In low-rise buildings, however, the roof area can easily compose from 50 to 75% of the above-ground shell. Thus, the roof can be a major contributor to energy losses and gains, and savings from roof reflectance change may significantly reduce the buildings total energy bill (Fig. 10).




Figure 10 – Comparison of relative roof area.
A savings will result for both buildings for a given roof reflectance change, but the relative savings for a low-rise building will be larger.

ROOF SURFACE PROPERTY CHANGES

The solar reflectance of a roof changes over time, thus changing the performance of the roof as originally installed. ORNL experience has shown that a black asphaltic surface becomes more reflective and that a white roof surface tends to become less reflective. This change is likely due to surface contamination, chemical reactions, and other factors. These changes can be either beneficial or detrimental to a building's energy demands.




Figure 11 – Effects of weathering.
Weathering tends to reduce the reflectance of a light roof and increase the reflectance of a dark roof.

Quantifying the change in a roof's reflectance during its life can be very difficult. If this change can be quantified, then this guide provides a method for evaluating its impact on energy use. If a user wishes to make estimates of the degradation of roof reflectance, this guide can also be used to study energy use impacts of a range of estimated changes in reflectance.

Section 4

EVALUATING ENERGY COST SAVINGS FROM A CHANGE IN ROOF REFLECTANCE

This guide provides a method for the user to estimate the cost savings from a change in roof reflectance. Steps to estimating these savings include:

- ! Selection of building type and climate data
- ! Determination of roof insulation R-value
- ! Determination of local energy costs and HVAC system efficiencies
- ! Determination of the change in roof reflectance
- ! Selection of the heating and cooling factors
- ! Completing the savings worksheet to estimate annual energy and cost (\$) savings

DATA REQUIREMENTS

Selection of Building Type and Climate Data

A building type, Ia, Ib, IIa, IIb, or III should be selected that best represents the building being evaluated. The building types are:

- I. A building with a ceiling plenum space (typically used for concealing HVAC duct and related equipment between the ceiling and the roof)
 - a Normal activity, e.g., normal occupancy and equipment loads
 - b High activity, e.g., high occupancy or high equipment loads
- II. A building without a ceiling plenum
 - a low activity and loads, e.g., a conditioned storage area
 - b high activity and loads, e.g., a retail area
- III. Energy intensive buildings or spaces (with or without a ceiling plenum), i.e., buildings which normally consume large amounts of energy per square foot such as:
 1. restaurant areas with high cooking loads
 2. office building areas with high equipment loads
 3. industrial building areas with high equipment loads
 4. some hospital areas, and potentially other buildings.

The building choice determines which of the sets of Cooling/Heating Factors tables (or figures) listed in Appendix D should be used.

Based on simulation results, these five building categories should represent most buildings reasonably well for an evaluation of energy savings related to roof reflectance change (see Appendix F).

The appropriate climate data, heating and cooling degree days and solar radiation values, can be selected from Appendix A. If the particular city of interest is not listed, data for the nearest city listed would be appropriate provided that a dramatic difference does not exist between climates. Solar radiation data listed in Appendix A do not consider the effects of water, snow, or shading on the annual global radiation received by a roof. The presence of snow tends to increase the benefits of a higher roof solar reflectance relative to a lower solar reflectance. Rain and shading tend to decrease the benefits. (See Interpreting Results discussion at the end of this section.)

Determination of Roof Insulation R-Value

The R-value required is the value for the roof insulation only since in most cases, insulation R-value dominates the total R-value of a roof. Typical R-values of common roofing materials are provided in the sidebar. These values are on a per inch basis and therefore must be multiplied by the insulation thickness if the table is used. Various sources are available if a more detailed list of roofing materials is needed. The NRCA *Roofing Materials Guide*¹ is a suggested source. If the roof has multiple layers of insulation, the total R-value is the sum of individual R-values for each layer, i.e., $R(\text{total}) = R1 + R2 + \dots$, etc.

Determination of Local Energy Costs and HVAC System Efficiencies

The energy cost savings that result from a change in roof reflectance will vary with local energy rates. Doubling the local cost for energy would double the estimate of savings. Thus, savings will be dependent on local per unit energy costs and any reduction in demand-related charges. Savings estimated using this guide include demand-related savings if energy costs in Appendix B are used. If local energy costs are used and demand reductions are not accounted for, savings estimates generated using this guide will be conservative.

If a particular building uses different fuel types for summer cooling and winter heating, such as electric cooling and gas heating, increasing roof reflectance may be desirable even in an area where there is a substantial heating season. This could occur if the cost per unit of energy is significantly less for the

INSULATION R-VALUES*

Insulation Type	R/inch (nominal) (hr-ft ² -EF/Btu-in)
Fiberglass	4.0
Expanded polystyrene	3.8
Extruded polystyrene	5.0
Phenolic	8.3
Isocyanurate	5.8-7.2
Fiberboard	2.8
Perlite	2.8

For homogenous insulation, the total R-value is:

$$\text{Total R} = \text{R/inch} \times \text{thickness} \\ \text{(inches)}$$

*The R/inch values vary for different manufacturers. Actual values should be obtained from manufacturer literature or the *Roofing Materials Guide* published by the NRCA (see footnote below).

¹*Roofing Materials Guide* (semiannual). National Roofing Contractors Association, Sect. 3, Rosemont, Illinois

heating fuel (e.g., gas) than for the cooling fuel (e.g., electricity), thus reducing the heating penalty relative to the cooling dollars saved as a result of increasing roof reflectance. If there is a substantial difference between cooling and heating fuels, a building in a climate that is not dominated significantly by the heating or cooling season may still produce substantial savings from roof reflectance change.

Energy costs should be obtained from local utilities. For electricity, the average cost per kWh should be obtained for the particular building size. This number is an average kWh cost based on standard kWh cost and typical demand costs for the particular building size. For rough approximations, average per unit energy costs can be taken from Appendix B. Note that these costs are for 1985 and may not be appropriate as listed. If these values are slightly out of date, an estimated escalation (a percent increase) could be applied to approximate current values. Cost histories may need to be examined here since projecting energy cost increases over long periods can lead to major errors.

Heating and cooling (HVAC) system operational costs are based on the amount of energy consumed by the heating or cooling system, but the increase in heating and decrease in cooling energy computed here represent what the HVAC system must add or remove from the building space. The energy added to or removed from the building space divided by the energy consumed by the HVAC system may be called the efficiency (heating) or COP (cooling). Efficiencies and COPs can have a wide range of values, depending on the type, age, condition, and size of the HVAC equipment. The efficiencies or COPs for the building systems being evaluated should be obtained from actual data on the systems if possible. If these are not available, using a cooling COP of 1.7 for older unitary (cooling) equipment or 2.2 for newer unitary equipment and a heating system efficiency of 75% for fossil fuel systems or 190% for heat pumps is recommended.

Determination of the Change in Roof Reflectance

The change in roof reflectance to be examined is determined based on manufacturer's data, values from Appendix C, or other estimates. Changes in surface infrared emittance are not considered in this guide for evaluating savings. This is done since surface infrared emittance has little dependence on surface color (solar reflectance).

Selection of the Heating and Cooling Factors

Heating and cooling energy factors can be selected from Appendix D. Using the appropriate table, these factors should be determined based on heating degree days, cooling degree days, and insulation R-value. Heating and cooling energy factors were developed using the computer-based building energy use simulation program DOE-2.1B (see Appendix F). This program incorporates a dynamic model which simulates building performance on an hourly basis. The program accounts for dominant factors that influence the energy use of a building including building construction, building mass, HVAC systems, weather, internal loads, and operational schedules. The variations found in these factors for different buildings resulted in the generalized building types of this guide.

COMPLETING THE SAVINGS WORKSHEET

The savings worksheet for calculating energy cost savings as a result of roof reflectance change is shown on the next page. The worksheet should be completed as follows:

Site Information

Enter the selected building type.

Enter the building location and corresponding climate data (the solar radiation value is entered in box [1] of Calculation of Estimated Energy Savings).

Enter the roof's insulation R-value and its surface area (surface area is entered in box [2] of Calculation of Estimated Energy Savings).

Cost of Energy for Heating and Cooling

A-B. Enter HVAC system performance data, COP and efficiency.

C-D. Enter energy costs by type in \$/million Btu's

(1 therm = 0.1 million Btu and 293 kWh or 7.15 gal. of #2 oil = 1 million Btu).

E-F. Calculate cooling and heating energy costs.

Calculation of Estimated Energy Savings

3. Enter the proposed change in roof reflectance.

4-5. Enter the appropriate heating and cooling factors from Appendix D.

6-7. Calculate estimated changes in heating and cooling energy.

Annual Cost Savings Estimate

8-10. Calculate estimated cooling cost reduction, heating cost increase, and net annual savings in dollars.

ENERGY SAVINGS ESTIMATES FOR HIGHER ROOF SOLAR REFLECTANCE WORKSHEET

SITE INFORMATION

Building Type: _____	Cooling Degree Days _____
Location: _____	Heating Degree Days _____
Roof Insulation R-value (hr-ft ² -°F/Btu): _____	Solar Radiation _____
	Appendix A
	Appendix A
	Appendix A

COST OF ENERGY FOR HEATING AND COOLING

(A)	(B)	(C)	(D)	(E)	(F)
COOLING SYSTEM COP	HEATING SYSTEM EFFICIENCY (%)	COOLING FUEL COST (\$/10 ⁶ Btu)	HEATING FUEL COST (\$/10 ⁶ Btu)	COOLING ENERGY COST (\$/10 ⁶ Btu) [C / A]	HEATING ENERGY COST (\$/10 ⁶ Btu) [(D / B) x 100]

specified by user specified by user specified by user or App. B specified by user or App. B

For calculation of energy costs: electricity - \$/10⁶ Btu = ¢/kWh x 2.93

natural gas - \$/10⁶ Btu = (\$/therm or \$/CCF) x 10 #2 fuel oil - \$/10⁶ Btu = \$/gal x 7.15

CALCULATION OF ESTIMATED ENERGY SAVINGS

(1)	(2)	(3)	(4)	(5)	(6)	(7)
SOLAR RADIATION (Btu/ft ² /day)	ROOF AREA (ft ²)	CHANGE IN REFLECTANCE	COOLING ENERGY FACTOR	HEATING ENERGY FACTOR	DECREASE IN COOLING ENERGY (10 ⁶ Btu/yr) (1 x 2 x 3 x 4) / 10 ⁶	INCREASE IN HEATING ENERGY (10 ⁶ Btu/yr) (1 x 2 x 3 x 5) / 10 ⁶

App. A specified by user specified by user App. D App. D

ANNUAL COST SAVINGS ESTIMATE

<div style="border: 1px solid black; padding: 5px; margin-bottom: 5px;"> (8) COOLING COST REDUCTION (\$/YR) 6 x E </div>	<div style="border: 1px solid black; padding: 5px; margin-bottom: 5px;"> (9) HEATING COST INCREASE (\$/YR) 7 x F </div>	=	<div style="border: 1px solid black; padding: 5px;"> (10) NET COST SAVINGS (\$/YR) 8 - 9 </div>
--	---	---	---

EXAMPLE: Roof Reflectance Change for an Office Building

A small office building in Albuquerque has 5,000 square feet of low-sloped roof. Re-roofing is being planned and use of a light-colored membrane having an estimated solar reflectance of 0.7 is being considered as opposed to a dark membrane with an estimated solar reflectance of 0.2. The lighter membrane will cost 20 cents more per sq. ft. (\$1000 added). The insulation R-value of the new roof will be 4 ft²-hr-F/Btu. The building is electrically cooled and gas heated. The building has a ceiling plenum used to conceal air distribution ducts.

Part A. Will energy cost savings from the light-colored membrane pay back its added cost within five years?

Solution

The building has a ceiling plenum and is not an intensive energy user. Thus, building Type Ia most nearly matches this building. Instead of obtaining current local energy costs, the user decides to use the energy cost rates provided in Appendix B as approximations. The estimated change in solar reflectance is $0.7 - 0.2 = 0.5$. The worksheet is completed as shown on the opposing page.

Conclusions

The roof reflectance change reduces energy use by 26.9 MBtu/year providing a net annual energy cost savings of approximately \$644/year. Payback of the additional expense of the light membrane will occur in 1.6 years ($\$1000 / \644). Although Albuquerque has a heating-season dominated year, savings from increasing roof reflectance are still substantial, and the payback period is less than five years.

Part B. Assume that the roof insulation for this building was R-8 instead of R-4 as in Part A above. Will the energy cost savings from the light-colored membrane still pay back within five years?

Solution

The new values needed in Part A as a result of the increased R-value of the roof are:

$$\text{R-Value} = 8$$

$$\text{Cooling Factor} = 5.2 \text{ (Appendix D)}$$

$$\text{Heating Factor} = 1.25 \text{ (Appendix D)}$$

Conclusions

Changing these values on the worksheet results in a savings of \$410 as a result of the reflectance change. Payback of the additional expense of the light membrane occurs in 2.5 years ($\$1000 / \$410 = 2.5$). The payback occurs within five years for a roof R-value of 8 as well.

ENERGY SAVINGS ESTIMATES FOR HIGHER ROOF SOLAR REFLECTANCE WORKSHEET

SITE INFORMATION

Building Type: <u>Ia - Office</u>	Cooling Degree Days <u>1316</u>
Location: <u>Albuquerque</u>	Heating Degree Days <u>4291</u> <small>Appendix A</small>
Roof Insulation R-value (hr-ft ² -°F/Btu): <u>4</u>	Solar Radiation <u>1828</u> <small>Appendix A</small>

COST OF ENERGY FOR HEATING AND COOLING

(A)	(B)	(C)	(D)	(E)	(F)
COOLING SYSTEM COP	HEATING SYSTEM EFFICIENCY (%)	COOLING FUEL COST (\$/10 ⁶ Btu)	HEATING FUEL COST (\$/10 ⁶ Btu)	COOLING ENERGY COST (\$/10 ⁶ Btu) [C / A]	HEATING ENERGY COST (\$/10 ⁶ Btu) [(D / B) x 100]
<u>1.7</u>	<u>75</u>	<u>31.9 (elec.)</u>	<u>4.7 (gas)</u>	<u>18.8</u>	<u>6.27</u>

specified by user specified by user specified by user or App. B specified by user or App. B

For calculation of energy costs: electricity - \$/10⁶ Btu = \$/kWh x 2.93

natural gas - \$/10⁶ Btu = (\$/therm or \$/CCF) x 10 #2 fuel oil - \$/10⁶ Btu = \$/gal x 7.15

CALCULATION OF ESTIMATED ENERGY SAVINGS

(1)	(2)	(3)	(4)	(5)	(6)	(7)
SOLAR RADIATION (Btu/ft ² /day)	ROOF AREA (ft ²)	CHANGE IN REFLECTANCE	COOLING ENERGY FACTOR	HEATING ENERGY FACTOR	DECREASE IN COOLING ENERGY (10 ⁶ Btu/yr) (1 x 2 x 3 x 4) / 10 ⁶	INCREASE IN HEATING ENERGY (10 ⁶ Btu/yr) (1 x 2 x 3 x 5) / 10 ⁶
<u>1828</u>	<u>5,000</u>	<u>0.5</u>	<u>8.3</u>	<u>2.4</u>	<u>37.9</u>	<u>11.0</u>

App. A specified by user specified by user App. D App. D

ANNUAL COST SAVINGS ESTIMATE

(8) COOLING COST REDUCTION (\$/YR) 6 x E <u>712</u>	(9) HEATING COST INCREASE (\$/YR) 7 x F <u>69</u>	=	(10) NET COST SAVINGS (\$/YR) 8 - 9 <u>643</u>
--	--	---	---

EXAMPLE: Roof Reflectance Change for Industrial and Retail Buildings

A supplier has suggested that he can coat smooth-surfaced roofs with a highly-reflective coating that will have attractive savings. The supplier claims the coating can be applied for a total cost of 20 cents/ sq. ft. and will increase the solar reflectance of a black roof by 0.6.

The owner of a manufacturing and retailing business is interested in the product. The specifications of the owner's buildings are:

Case 1. Industrial manufacturing building located in Minneapolis, Minn.
The building has 7,000 sq. ft. of roof insulated to R-8 and does not have a ceiling plenum.

Case 2. Retail sales building located in Dallas, Texas. The building has 10,000 sq. ft. of roof insulated to R-8 and has a ceiling plenum.

Both buildings are electrically cooled and gas heated. If the owner requires a payback on the investment of two years, will the coating be acceptable to the owner if it can perform as claimed?

Solution: Case 1

The building is for industrial manufacturing and has extensive machinery. The building is best described by Building Type III. The coating will cost \$1400 ($\$0.20/\text{sq. ft.} \times 7,000 \text{ sq. ft.}$). The worksheet is completed as shown on the opposing page.

Conclusion: Case 1

Using the heating and cooling costs provided in Appendix B, the roof reflectance change reduces the net annual energy cost for the building by approximately \$285. The payback is substantially longer than the two years required by the owner ($\$1400 / \$285 = 4.9$ years).

Solution: Case 2

The building has a ceiling plenum, is operated 7 days per week, and has large cooling loads due to extensive lighting. The building is best described by Building Type Ib. Per Appendix B, average energy costs are 9.9 cents/kWh for electricity and 54 cents/CCF for gas. The appropriate worksheet data for this building is enclosed in parentheses on the opposing worksheet for comparison to Case I.

Conclusions: Case 2 and Comparison

Using the heating and cooling costs provided in Appendix B, the roof reflectance change reduces the net annual energy cost for the Case 2 building by approximately \$1175. The coating will cost \$2000 ($\$0.20/\text{sq. ft.} \times 10,000 \text{ sq. ft.}$). If the roof's reflectance is increased by 0.6, the energy cost savings will easily meet the owners requirement of investment payback within two years ($\$2000 / \$1175 = 1.7$) if local energy costs are comparable to those used from Appendix B. Although the building types are different, the difference in climate is the main reason for the dramatic savings difference between Cases 1 and 2.

ENERGY SAVINGS ESTIMATES FOR HIGHER ROOF SOLAR REFLECTANCE WORKSHEET

SITE INFORMATION

Building Type: <u>Industrial (Retail)</u> <small>(Ib)</small>	Cooling Degree Days <u>585 (2754)</u>
Location: <u>Minneapolis (Dallas)</u>	Heating Degree Days <u>8158 (2290)</u> <small>Appendix A</small>
Roof Insulation R-value (hr-ft ² -°F/Btu): <u>8</u>	Solar Radiation <u>1170 (1468)</u> <small>Appendix A</small>

COST OF ENERGY FOR HEATING AND COOLING

(A)	(B)	(C)	(D)	(E)	(F)
COOLING SYSTEM COP	HEATING SYSTEM EFFICIENCY (%)	COOLING FUEL COST (\$/10 ⁶ Btu)	HEATING FUEL COST (\$/10 ⁶ Btu)	COOLING ENERGY COST (\$/10 ⁶ Btu) [C / A]	HEATING ENERGY COST (\$/10 ⁶ Btu) [D / B] x 100]
<u>1.7</u>	<u>75</u>	<u>19.8 (29.0)</u>	<u>6.08 (5.4)</u>	<u>11.6 (17.1)</u>	<u>8.1 (7.2)</u>

specified by user specified by user specified by user of App. B specified by user of App. B

For calculation of energy costs: electricity - \$/10⁶ Btu = e/kWh x 2.93
 natural gas - \$/10⁶ Btu = (\$/therm or \$/CCF) x 10 #2 fuel oil - \$/10⁶ Btu = \$/gal x 7.15

CALCULATION OF ESTIMATED ENERGY SAVINGS

(1)	(2)	(3)	(4)	(5)	(6)	(7)
SOLAR RADIATION (Btu/m ² /day)	ROOF AREA (ft ²)	CHANGE IN REFLECTANCE	COOLING ENERGY FACTOR	HEATING ENERGY FACTOR	DECREASE IN COOLING ENERGY (10 ⁶ Btu/yr) (1 x 2 x 3 x 4) / 10 ⁶	INCREASE IN HEATING ENERGY (10 ⁶ Btu/yr) (1 x 2 x 3 x 5) / 10 ⁶
<u>1170 (1468)</u>	<u>7000 (10,000)</u>	<u>0.6</u>	<u>5 (7.8)</u>	<u>0 (0)</u>	<u>24.6 (68.7)</u>	<u>0 (0)</u>

ANNUAL COST SAVINGS ESTIMATE

(8) COOLING COST REDUCTION (\$/YR) 6 x E <u>285 (1175)</u>	(9) HEATING COST INCREASE (\$/YR) 7 x F <u>0 (0)</u>	=	(10) NET COST SAVINGS (\$/YR) 8 - 9 <u>285 (1175)</u>
---	---	---	--

INTERPRETING RESULTS

The information included in this document provides a method for estimating the savings for a change in roof solar reflectance and shows that savings decrease with increased roof insulation R-value. However, the factors provided here do not account for changes in heating or cooling energy use caused by changes in R-value of roof insulation. The factors do account for the interactive effect of roof insulation R-value on potential savings from a change in roof solar reflectance. Therefore, the data presented here cannot be used to evaluate effects of insulation R-value on energy use or costs, and the user can only evaluate impacts from solar reflectance given a roof insulation R-value as a starting point.

In terms of dollar savings, increasing roof reflectance may or may not be cost effective. A positive dollar savings indicates reduced energy costs from the reflectance increase. A negative result indicates an increase in energy costs and thus a penalty for the increase in roof reflectance. Users must evaluate the benefits of the cost savings and the costs of achieving the increased roof reflectance to determine whether an investment in the increased reflectance is attractive.

Because the effects of snow, rain, and shading are not explicitly addressed in the heating and cooling factors or in the solar radiation data, some adjustments to the estimates of changes in heating and cooling energy due to increased roof reflectance may be required if snow, rain, or shading are judged to have a significant impact. Snow tends to increase benefits, and thus the savings estimates will be more conservative if snow is ignored. Rain will have an impact on savings, but if most of the daytime hours during the cooling season do not have rainfall, the effects of rain can usually be ignored. Significant shading on the roof (more than 10% shaded for most of the middle six hours of the day) by trees, buildings, or other causes must be considered, and the judgment of a professional is probably required to make an estimate of the impacts of significant shading.

BIBLIOGRAPHY

- "Acrylic Roof Mastic: Key Factor in 'Future' Building," *Energy Management Technology*, May/June 1986.
- Anderson, R. W. and Associates. "Evaluation of Energy Conservation Measures for Roofs," Sponsored by the Ministry of Planning and Development. Government of Pakistan. Prepared for the National Energy Conservation Center. Islamabad, Pakistan. Feb. 1988.
- ASHRAE Handbook -- 1985 Fundamentals, American Society of Heating, Refrigerating, and Air Conditioning Engineers, Inc., Atlanta, Georgia. 1985.
- Associated Press -- Gainesville, Florida. "Professor Says Aluminum Will Foil Summer's Heat," Sunday, June 22, 1986.
- Backenstow, D. E. "Comparison of White vs. Black Surfaces for Energy Conservation," 8th Conference on Roofing Technology. NBS/NCRA. April 16-17, 1987.
- Baker, M. C. *ROOFS -- Design, Application, and Maintenance*, sponsored by the National Research Council of Canada. Multiscience Publications, Limited. 1980.
- Barber, J. "Re-Roofing Slashes Chain's Cooling Costs." *Energy User News*, Monday, March 26, 1984.
- Busching, H. W., and Porcher Jr., J. P. "Roofing Industry Perspective and Research Capability," Oak Ridge National Laboratory. ORNL/SUB/82-22293/2. 1985.
- Chang, T., and Busching, H. W. "Energy Savings Potential of Roofing Research," ORNL/SUB/82-22293/1. Report prepared under Purchase Order No. 19X22293V for ORNL by Clemson University. December 1983.
- Childs, K. W. "The Use of Roof Temperature Modeling to Predict Necessary Conditions for Locating Wet Insulation with Infrared Thermography," Oak Ridge National Laboratory. K/CSD/TM.-58. 1985.
- Coursey, C. R., personal communication on independent laboratory tests of hemispherical spectral reflectance for air mass 1.5 for white hypalon product, 1989.
- Cullen, W. C. "Solar Heating, Radiative Cooling, and Thermal Movement: Their Effects on Built-Up Roofing," NBS Technical Note 231. December 16, 1963.
- Cullen, W. C., and Appleton, W. H. "Effects of Insulation on the Weathering of Smooth-Surfaced Built-Up Roofs Exposed to Solar Heating," *American Roofer and Building Improvement Contractor*, March 1963.
- DeMuth, J. "White vs. Black: Does Membrane Color Matter?" *Roofing Spec*, May 1986.

DOE-2 Reference Manual -- Parts 1 and 2. Prepared for the US Department of Energy under Contract W-7405-ENG-8. Lawrence Berkeley Laboratory and Los Alamos National Laboratory LA-7689-M Ver. 2.1. LBL-8706. Rev. 1. May 1980.

Dubin, F. S., and Long Jr., C. G. *Energy Conservation Standards for Building Design Construction and Operation*, McGraw-Hill Book Company, 1978.

Griffin, C. W. "Cost Savings with Heat-Reflective Roof Coatings," *Plant Engineering*, pp. 98-102. July 10, 1980.

Griggs, E. I., and Courville, G. E. "Changes in Building Heating and Cooling Requirements Due to a Reduction in the Roof's Solar Absorptance," ASHRAE/DOE/BTECC Conference: Thermal Performance of the Exterior Envelopes of Buildings III. December 2-5, 1985. ASHRAE SP49, 1986.

Griggs, E. I., and Shipp, P. H. "The Impact of Surface Reflectance on The Thermal Performance of Roofs: An Experimental Study," ASHRAE Paper OT-88-12-4. Presented at ASHRAE meeting. Ottawa, Ontario. June 28, 1988.

"Industrial Electricity Press by Cities," *Energy User News*, Vol. 11. No. 12. p. 10. Monday, March 24, 1986.

Keeton, J. R., and Alumbaugh, R. L., "Energy Factors and Temperature Distribution in Insulated Built-Up Roofs," TN N-1600. Civil Engineering Laboratory. Naval Construction Battalion Center. Port Hvenee, California. February 1981.

Knapp, C. L., Stoffel, T. L., and S. D. Whitaker. "Insolation Data Manual," SERI/SP-755-789. October 1980.

Martin, M., and Berdahl, P. "Characteristics of Infrared Sky Radiation in the United States," *Solar Energy*, Vol. 33. No. 3/4. pp 321-336. 1984.

Probert, S. D., and Thirst, T. J. "Design and Performance of Roofs," *Applied Energy*, Vol. 6. pp. 79-97. 1980.

Reagan, J. A., and Acklam, D. M. "Solar Reflectivity of Common Building Materials and Its Influence on the Roof Heat Gain of Typical Southwestern USA Residences," *Energy and Buildings*, Vol. 2. pp. 237-248. 1979.

Robinson, J. N. "The Assessment of Roofing Research--An Interim Report," ORNL/TM-7460. Oak Ridge National Laboratory. July 1981.

Rossiter Jr., W. J., and Mathey, R. G. "Effect of Insulation on the Surface Temperature of Roof Membranes," National Bureau of Standards. NBSIR 76-987. February 1976.

Shipp, P. H., and Griggs, E. I. “Impact of Color on the Thermal Performance of Roofs,” Paper No. 38. Presented at the 1988 meeting of the Rubber Division, American Chemical Society. Dallas, Texas. April 19-22, 1988.

Shuman, E. C. “Field Measurements of Heat Flow Through a Roof with Saturated Thermal Insulation and Covered with Black and White Granules,” Thermal Insulation Performance. ASTM STP 718. D. L. McElroy and R. P. Tye, eds., American Society for Testing and Materials. pp. 519-539. 1980.

Swinbank, W. C. “Long-Wave Radiation from Clear Skies,” *Quart. J. R. Meteorological Society*, Vol. 89. No. 381. p. 339. July, 1963.

Talbert, S. G. “Energy Savings of Buildings Using Aluminum Roof Flakes,” Energy Savings Report. Prepared by Battelle Columbus Laboratories for Transmet Corporation. Columbus, Ohio.

Appendix A WEATHER DATA

(Data are from Knapp et al, 1980—see Bibliography. More specific data may be obtained from NOAA, Asheville, NC, a utility, or a local university.)

	Annual Cooling Degree Days (65 Base)	Annual Heating Degree Days (65 Base)	Annual Average Solar Radiation (avg, total daily, Btu/ft ² -day)				
ALABAMA				Long Beach	985	1606	1597.7
Birmingham	1928	2844	1344.7	Los Angeles	614	1818	1593.8
Mobile	2576	1683	1384.7	Mount Shasta	284	5890	1491
Montgomery	2237	2268	1387.9	Needles	4235	1427	1861
ALASKA				Oakland	128	2909	1535.2
Annette	13	7052	794.6	Red Bluff	1903	2687	1581.1
Barrow	0	20264	595	Sacramento	1157	2842	1642.9
Bethel	0	13203	732.4	San Diego	722	1507	1598
Bettles	16	15925	765.4	San Francisco	108	3042	1552.8
Big Delta	32	13698	811.5	Santa Maria	83	3053	1607.9
Fairbanks	50	14342	767.8	COLORADO			
Gulkana	9	13936	832.2	Colorado Springs	461	6473	1594.1
Homer	0	10363	837.6	Denver	625	6016	1568.4
Juneau	0	9005	682.7	Eagle	117	8426	1594.3
King Salmon	0	11584	793.9	Grand Junction	1139	5603	1658.7
Kodiak	0	8860	796.7	Pueblo	981	5393	1622.7
Kotzebue	0	16038	744.8	CONNECTICUT			
McGrath	13	14486	733.5	Hartford	583	6349	1058.3
Nome	0	14324	737.6	DELAWARE			
Summit	0	14368	761.3	Wilmington	992	4939	1207.7
Yakutat	0	9533	663.9	DISTRICT OF COLUMBIA			
ARIZONA				Washington	940	5009	1208.4
Phoenix	3506	1552	1869.4	FLORIDA			
Prescott	882	4455	1813.3	Apalachicola	2662	1361	1473.8
Tucson	2813	1751	1872.3	Daytona Beach	2918	902	1458.1
Winslow	1202	4732	1801.9	Jacksonville	2596	1327	1438.2
Yuma	4194	1010	1923.7	Miami	4037	205	1472.9
ARKANSAS				Orlando	3226	733	1486.7
Fort Smith	2021	3335	1404.1	Tallahassee	2561	1562	1432.6
Little Rock	1924	3353	1404.4	Tampa	3366	716	1492.1
CALIFORNIA				West Palm Beach	3785	299	1438.1
Bakersfield	2178	2183	1749.2				
Daggett	2729	2201	1842.8				
Fresno	1670	2650	1710.8				

GEORGIA				MARYLAND			
Atlanta	1588	3094	1345.3	Baltimore	1107	4729	1215
Augusta	1994	2547	1361.6	MASSACHUSETTS			
Macon	2293	2239	1379.2	Boston	661	5620	1104.7
Savannah	2317	1951	1364.5	MICHIGAN			
HAWAII				Alpena	207	8518	1086.1
Hilo	3065	0	1385.1	Detroit	742	6228	1120
Honolulu	4221	0	1638.7	Flint	437	7040	1075.1
Lihue	3719	0	1524.2	Grand Rapids	574	6800	1135.3
IDAHO				Sault Ste. Marie	139	9193	1041.9
Boise	713	5832	1495.5	Traverse City	374	7697	1083.2
Lewiston	657	5463	1210.1	MINNESOTA			
Pocatello	436	7061	1529.2	Duluth	175	9756	1064.3
ILLINOIS				International Falls	175	10546	1088.2
Chicago	923	6125	1215.1	Minneapolis/ St. Paul	585	8158	1170.2
Moline	893	6394	1223.6	Rochester	473	8226	1156.1
Springfield	1116	5557	1301.5	MISSISSIPPI			
INDIANA				Jackson	2320	2299	1408.6
Evansville	1363	4628	1261.8	Meridian	2230	2387	1369.9
Fort Wayne	747	6208	1122.7	MISSOURI			
Indianapolis	974	5576	1165	Columbia	1269	5081	1327.6
South Bend	695	6462	1138	Kansas City	1283	5357	1340
IOWA				Springfield	1381	4568	1362.1
Burlington	994	6149	1306	St. Louis	1474	4748	1326.6
Des Moines	927	6709	1311.8	MONTANA			
Mason City	580	7900	1288.5	Billings	497	7265	1324.7
Sioux City	931	6952	1310.2	Cut Bank	139	9032	1237.6
KANSAS				Dillon	198	8354	1369.6
Dodge City	1409	5045	1560.2	Glasgow	437	8968	1217.8
Goodland	923	6118	1528.6	Great Falls	338	7652	1262.3
Topeka	1361	5242	1384.8	Helena	256	8190	1262.4
Wichita	1672	4685	1502.3	Lewistown	254	8586	1240.2
KENTUCKY				Miles City	751	7888	1299.7
Lexington	1197	4729	1219.4	Missoula	187	7931	1168.5
Louisville	1267	4644	1215.7	NEBRASKA			
LOUISIANA				Grand Island	1035	6424	1405
Baton Rouge	2585	1669	1378.5	North Omaha	949	6601	1320.5
Lake Charles	2738	1498	1364.6	North Platte	801	6743	1444.6
New Orleans	2705	1463	1437	Scottsbluff	666	6773	1424.7
Shreveport	2538	2165	1426.1	NEVADA			
MAINE				Elko	342	7483	1625.5
Caribou	128	9632	1063.1	Ely	207	7814	1672.3
Portland	252	7497	1050.6	Las Vegas	2945	2601	1864.2
				Lovelock	684	5989	1790.5

Reno	328	6021	1760.7				
Tonopah	630	5899	1845.5	OKLAHOMA			
Winnemucca	407	6628	1647.6	Oklahoma City	1876	3694	1461.3
				Tulsa	1948	3679	1373.3
NEW HAMPSHIRE				OREGON			
Concord	347	7358	1053	Astoria	13	5294	1000.2
NEW JERSEY				Burns	288	7211	1389.9
Newark	1022	5033	1165.3	Medford	562	4928	1352.9
NEW MEXICO				North Bend	0	4687	1219.2
Albuquerque	1316	4291	1827.5	Pendleton	655	5240	1259.1
Clayton	767	5211	1669.8	Portland	299	4792	1066.8
Farmington	749	5711	1766.3	Redmond	169	6642	1383.4
Roswell	1559	3695	1810	Salem	230	4851	1127.2
Truth or				PACIFIC ISLANDS			
Consequences	1557	3391	1859.9	Koror Island	6007	0	1503.9
Tucumcari	1355	4046	1723.5	Kwajalein Island	6163	0	1620.5
Zuni	472	5814	1744	Wake Island	5454	0	1720.1
NEW YORK				PENNSYLVANIA			
Albany	572	6887	1065.8	Allentown	770	5827	1138.9
Binghamton	369	7285	995.6	Erie	373	6851	1058.7
Buffalo	436	6926	1034.3	Harrisburg	1024	5224	1149.8
Massena	342	8237	1041.7	Philadelphia	1103	4864	1168.7
New York City				Pittsburgh	646	5929	1068.9
(Central Park)	1067	4847	1098.9	Wilkes-Barre/			
New York City				Scranton	607	6277	1086.4
(LaGuardia)	1048	4909	1171.4	PUERTO RICO			
Rochester	531	6718	1043	San Juan	4981	0	1639.6
Syracuse	551	6678	1034.5	RHODE ISLAND			
NORTH CAROLINA				Providence	531	5971	1112.2
Asheville	871	4235	1311.9	SOUTH CAROLINA			
Cape Hatteras	1550	2731	1375	Charleston	2077	2146	1345.1
Charlotte	1595	3217	1344.4	Columbia	2086	2597	1380.4
Greensboro	1341	3825	1343.3	Greenville/			
Raleigh/Durham	1393	3514	1295.5	Spartanburg	1571	3163	1346.6
NORTH DAKOTA				SOUTH DAKOTA			
Bismarck	486	9043	1248.4	Huron	711	8053	1276.1
Fargo	472	9270	1203.4	Pierre	857	7677	1349.2
Minot	369	9407	1178.3	Rapid City	6661	7322	1341.3
OHIO				Sioux Falls	718	7837	1290.1
Akron/Canton	6223	634	1110.5	TENNESSEE			
Cincinnati				Chattanooga	1634	3505	1245.1
(Covington,KY)	1080	5069	1158.5	Knoxville	1568	3478	1273.4
Cleveland	612	6152	1090.6	Memphis	2029	3226	1365.9
Columbus	808	5701	1122.9	Nashville	1694	3695	1269.7
Dayton	936	5639	1160.8				
Toledo	684	6381	1133				
Youngstown	517	6426	1045.2				

TEXAS				VIRGINIA			
Abilene	2466	2610	1554.3	Norfolk	1440	3487	1325.2
Amarillo	1433	4181	1659.2	Richmond	1352	3938	1248
Austin	2907	1737	1476.4	Roanoke	1030	4306	1269.5
Brownsville	3874	650	1547.9	WASHINGTON			
Corpus Christi	3474	929	1520.5	Olympia	101	5530	1001.1
Dallas	2754	2290	1468.1	Seattle/Tacoma	128	5184	1052.7
Del Rio	3362	1523	1515.9	Spokane	387	6835	1223.8
El Paso	2097	2677	1899.7	Yakima	479	6008	1281.2
Fort Worth	2587	2381	1474.9	WEST VIRGINIA			
Houston	2889	1433	1351.1	Charleston	1055	4590	1123.3
Laredo	4136	875	1550.5	Huntington	1098	4622	1176.2
Lubbock	1647	3544	1766	WISCONSIN			
Lufkin	2592	1939	1438.8	Eau Claire	459	8388	1132.3
Midland/Odessa	2250	2621	1802.4	Green Bay	385	8096	1142.5
Port Arthur	2797	1517	1404.4	La Crosse	695	7416	1160.6
San Angelo	2702	2239	1567.9	Madison	459	7729	1190.9
San Antonio	2993	1570	1499	Milwaukee	450	7443	1191.2
Sherman	2336	2864	1441.1	WYOMING			
Waco	2862	2057	1467.1	Casper	457	7555	1564.7
Wichita Falls	2610	2903	1520.2	Cheyenne	326	7254	1490.7
UTAH				Rock Springs	227	8410	1635
Bryce Canyon	40	9131	1739.5	Sheridan	445	7708	1330.1
Cedar City	614	6136	1742.8	VERMONT			
Salt Lake City	927	5981	1603.1	Burlington	396	7875	1020.7

Appendix B

ENERGY COSTS FOR SPECIFIC CITIES (1985)

Local energy costs should be used for the calculations in this manual. The data here are for illustrative use in the examples or for quick estimates that will be verified later.

SMALL COMMERCIAL ELECTRICITY	Cost Per kWh (cents/kWh)	
	Cooling	Heating
Albuquerque, New Mexico		
Small Commercial Basic Electricity Without Demand	9.295	7.471
Small Commercial Time-of-use With Demand	10.884	8.424
Atlanta, Georgia		
Small Commercial Basic Electricity Without Demand	10.723	10.577
Birmingham, Alabama		
Small Commercial Basic Electricity With Demand	8.464	8.191
Boston, Massachusetts		
Small Commercial Basic Electricity With Demand	14.09	12.872
Small Commercial Time-of-use With Demand	16.184	14.454
Chicago, Illinois		
Small Commercial Basic Electricity With Demand	11.233	10.104
Dallas, Texas		
Small Commercial Basic Electricity With Demand	9.899	9.545
Denver, Colorado		
Small Commercial Basic Electricity With Demand	8.37	8.994
Detroit, Michigan		
Small Commercial Basic Electricity Without Demand	9.016	8.891
Kansas City, Missouri		
Small Commercial Basic Electricity With Demand	8.212	8.212
Los Angeles, California		
Small Commercial Basic Electricity With Demand	7.381	7.381
Small Commercial Time-of-use With Demand	8.844	9.917
Louisville, Kentucky		
Small Commercial Basic Electricity Without Demand	7.74	6.47
Minneapolis, Minnesota		
Small Commercial Basic Electricity With Demand	6.762	5.909
Small Commercial Time-of-use With Demand	5.85	5.767

New York, New York		
Small Commercial Basic Electricity Without Demand	21.175	18.013
Philadelphia, Pennsylvania		
Small Commercial Basic Electricity Without Demand	12.118	10.046
San Francisco, California		
Small Commercial Basic Electricity Without Demand	4.574	7.807
Small Commercial Basic Electricity With Demand	7.472	7.472
Small Commercial Time-of-use Without Demand	8.358	8.58
Small Commercial Time-of-use With Demand	7.924	7.92
Seattle, Washington		
Small Commercial Basic Electricity With Demand	2.18	2.32
Tulsa, Oklahoma		
Small Commercial Basic Electricity Without Demand	4.277	4.485
Washington, D. C.		
Small Commercial Basic Electricity Without Demand	10.451	8.277
Small Commercial Basic Electricity With Demand	11.063	8.753

SMALL COMMERCIAL NATURAL GAS

Cost Per CCF (\$/CCF)

	Cooling	Heating
Albuquerque, New Mexico	\$0.50	\$0.47
Atlanta, Georgia	\$0.59	\$0.61
Birmingham, Alabama	\$0.56	\$0.56
Boston, Massachusetts	\$0.68	\$0.70
Chicago, Illinois	\$0.51	\$0.55
Dallas, Texas	\$0.49	\$0.54
Denver, Colorado	\$0.44	\$0.44
Detroit, Michigan	\$0.61	\$0.65
Kansas City, Missouri	\$0.48	\$0.50
Los Angeles, California	\$0.80	\$0.80
Louisville, Kentucky	\$0.47	\$0.47
Minneapolis, Minnesota	\$0.61	\$0.61
New York, New York	\$1.04	\$1.01
Philadelphia, Pennsylvania	\$0.73	\$0.67
San Francisco, California	\$0.67	\$0.67
Seattle, Washington	\$0.68	\$0.65
Tulsa, Oklahoma	\$0.50	\$0.48
Washington, D. C.	\$0.77	\$0.81

Appendix C REFERENCE REFLECTANCES

The reflectance values listed here are illustrative of typical ranges and were obtained from the sources indicated (see Bibliography). Reflectance values for a specific product that are known or can be measured should be used when available.

COLOR CLASSIFICATION FOR OPAQUE BUILDING MATERIALS

(from Reagan and Acklam, 1979)

Surface Color Code	Reflectance
Very light	0.75
Light	0.65
Medium	0.45
Dark	0.25
Very dark	0.10
Very light:	
Smooth building material surfaces covered with a fresh or clean stark white paint or coating	
Light:	
Masonry, textured, rough wood, or gravel (roof) surfaces covered with a white paint or coating	
Medium:	
Off-white, cream, buff or other light colored brick, concrete block, or painted surfaces and white-chip marble covered roofs	
Dark:	
Brown, red or other dark colored brick, concrete block, painted or natural wool walls and roofs with gravel, red tile, stone, or tan to brown shingles	
Very dark:	
Dark brown, dark green or other very dark colored painted, coated, or shingled surfaces	

GENERAL SURFACES

Surface Color Or Material	Reflectance
(from Probert and Thirst, 1980)	
Black	0.05
Dark Grey	0.15-.20
Light Grey	0.35
White	0.55
Copper-tarnished	0.20
Copper-oxidized	0.35
(from Baker, 1980)	
Copper	0.35
Aluminum	0.40
Galvanized Iron	0.10
Asbestos-Cement	0.20
Smooth-surface Asphalt	0.07
Grey Gravel	0.25
White Gravel	0.50
Concrete Paving	0.35

COATED AND BUILT-UP ROOFS

(from Reagan and Acklam, 1979)

Description	Reflectance
Pea gravel covered	
Dark blend	0.12
Medium blend	0.24
Light blend	0.34
White coated	0.65
Crushed used brick, red, covered	0.34
White marble chips covered	0.49
Flexstone or mineral chip roof type, white	0.26
Polyurethane foam, white coated	0.70
Same with tan coating	0.41
Silver, aluminum painted tar paper	0.51
Tarpaper, ``weathered''	0.41

SAMPLES OF MATERIALS USED ON ROOFS

Description	Reflectance
(from Coursey)	
White hypalon	0.780
(from Talbert)	
Trocal SMA (PVC base)	0.285
Derbigum HPS (Modified Bitumen)	0.580
Sure Seal, Design A (EPDM)	0.124
SPM System (EPDM)	0.108
Awaplan Regular (Modified Bit.)	0.067
Awaplan Welding (Modified Bit.)	0.244
SPM 60 (EPDM)	0.076
Aluminum Fiber Coating, 1.5#	0.530
Aluminum Fiber Coating, 3.0#	0.364
Rolled Aluminum Flake	0.695
Unrolled Aluminum Flake	0.584
Rolled Coated Aluminum Flake	0.542
Unrolled Coated Aluminum Flake	0.536
Plain Steep Asphalt	0.156
Gravel Coated Asphalt	0.234

Appendix D COOLING AND HEATING FACTORS

The cooling and heating factors are given in this appendix for the five building types (Ia, Ib, IIa, IIb, III) listed in Section 4 (also see Appendix F). The same data are given first in tabular form and then repeated graphically. The values are developed from simulations of the buildings using the DOE-2.1B computer code. Annual heating and cooling energies were calculated for different solar reflectances and fixed roof insulation. Calculations were made for a minimum of 12 locations. Heating and cooling factors were derived by dividing the heating and cooling energy values by roof area and average daily solar flux. Curve fits were made of these factors, and the data presented here are from the fitted curves.

CDD = Cooling Degree Days
HDD = Heating Degree Days

COOLING FACTORS FOR BLDG. Ia					HEATING FACTORS FOR BLDG. Ia				
CDD	R=2	R=4	R=8	R=16	HDD	R=2	R=4	R=8	R=16
350	6.53	4.17	2.56	1.45	0	0.00	0.00	0.00	0.00
550	8.33	5.93	3.74	2.10	400	0.36	0.23	0.12	0.06
750	9.48	6.80	4.30	2.41	800	0.72	0.45	0.24	0.12
950	10.36	7.42	4.69	2.62	1200	1.06	0.67	0.36	0.18
1150	11.08	7.91	4.99	2.79	1600	1.39	0.88	0.48	0.24
1350	11.71	8.31	5.25	2.93	2000	1.71	1.08	0.59	0.29
1550	12.26	8.67	5.47	3.05	2400	2.02	1.28	0.70	0.35
1750	12.75	8.98	5.66	3.16	2800	2.32	1.47	0.81	0.40
1950	13.20	9.26	5.84	3.25	3200	2.61	1.66	0.92	0.46
2150	13.62	9.51	6.00	3.34	3600	2.89	1.84	1.02	0.51
2350	14.00	9.75	6.15	3.42	4000	3.15	2.02	1.12	0.56
2550	14.36	9.97	6.28	3.49	4400	3.41	2.19	1.22	0.61
2750	14.70	10.17	6.41	3.56	4800	3.65	2.35	1.32	0.66
2950	15.02	10.37	6.53	3.63	5200	3.88	2.51	1.41	0.71
3150	15.33	10.55	6.64	3.69	5600	4.11	2.66	1.50	0.76
3350	15.62	10.72	6.75	3.75	6000	4.32	2.81	1.59	0.81
3550	15.90	10.89	6.85	3.81	6400	4.52	2.95	1.68	0.86
3750	16.16	11.04	6.95	3.86	6800	4.71	3.08	1.76	0.90
3950	16.42	11.19	7.04	3.91	7200	4.89	3.21	1.84	0.95
4150	16.67	11.34	7.13	3.96	7600	5.06	3.34	1.92	0.99
4350	16.90	11.48	7.22	4.00	8000	5.21	3.45	2.00	1.03
					8400	5.36	3.56	2.07	1.08
					8800	5.50	3.67	2.14	1.12
					9200	5.62	3.77	2.21	1.16

COOLING FACTORS FOR BLDG. Ib					HEATING FACTORS FOR BLDG. Ib				
CDD	R=2	R=4	R=8	R=16	HDD	R=2	R=4	R=8	R=16
350	9.97	6.63	3.78	2.02	0	0.00	0.00	0.00	0.00
550	12.17	8.05	4.64	2.49	400	0.27	0.00	0.00	0.00
750	13.67	9.02	5.23	2.81	800	0.56	0.00	0.00	0.00
950	14.82	9.77	5.68	3.06	1200	0.87	0.00	0.00	0.00
1150	15.75	10.37	6.04	3.26	1600	1.20	0.16	0.00	0.00
1350	16.52	10.87	6.34	3.43	2000	1.54	0.27	0.00	0.00
1550	17.19	11.30	6.60	3.57	2400	1.89	0.40	0.00	0.00
1750	17.78	11.69	6.83	3.70	2800	2.24	0.55	0.00	0.00
1950	18.31	12.02	7.04	3.81	3200	2.61	0.72	0.13	0.00
2150	18.78	12.33	7.22	3.91	3600	2.97	0.90	0.17	0.02
2350	19.21	12.61	7.39	4.00	4000	3.33	1.08	0.22	0.02
2550	19.61	12.87	7.55	4.09	4400	3.68	1.28	0.27	0.03
2750	19.97	13.10	7.69	4.17	4800	4.02	1.47	0.32	0.04
2950	20.32	13.33	7.82	4.24	5200	4.35	1.67	0.37	0.05
3150	20.63	13.53	7.95	4.31	5600	4.67	1.85	0.43	0.06
3350	20.93	13.72	8.06	4.37	6000	4.96	2.04	0.49	0.07
3550	21.21	13.91	8.17	4.43	6400	5.24	2.21	0.55	0.08
3750	21.48	14.08	8.28	4.49	6800	5.49	2.36	0.60	0.09
3950	21.73	14.24	8.38	4.54	7200	5.71	2.50	0.66	0.11
4150	21.97	14.40	8.47	4.59	7600	5.90	2.62	0.72	0.13
4350	22.20	14.55	8.56	4.64	8000	6.05	2.72	0.77	0.14
					8400	6.17	2.78	0.82	0.16
					8800	6.25	2.82	0.87	0.18
					9200	6.28	2.83	0.92	0.20

COOLING FACTORS FOR BLDG. IIa					HEATING FACTORS FOR BLDG. IIa				
CDD	R=2	R=4	R=8	R=16	HDD	R=2	R=4	R=8	R=16
350	9.62	6.01	3.34	1.76	0	0.00	0.00	0.00	0.00
550	10.92	6.90	3.93	2.09	400	0.83	0.50	0.28	0.17
750	12.16	7.73	4.49	2.40	800	1.65	0.98	0.54	0.33
950	13.32	8.51	5.00	2.69	1200	2.47	1.43	0.79	0.48
1150	14.40	9.24	5.47	2.95	1600	3.29	1.86	1.02	0.62
1350	15.41	9.92	5.89	3.18	2000	4.10	2.26	1.24	0.75
1550	16.34	10.55	6.27	3.40	2400	4.91	2.63	1.45	0.87
1750	17.20	11.13	6.61	3.59	2800	5.71	2.99	1.65	0.99
1950	17.98	11.65	6.90	3.75	3200	6.51	3.31	1.83	1.09
2150	18.69	12.13	7.15	3.89	3600	7.31	3.61	1.99	1.18
2350	19.32	12.55	7.36	4.01	4000	8.10	3.89	2.15	1.27
2550	19.88	12.92	7.53	4.11	4400	8.89	4.14	2.29	1.34
2750	20.36	13.24	7.65	4.18	4800	9.67	4.36	2.41	1.41
2950	20.77	13.51	7.73	4.22	5200	10.45	4.56	2.52	1.47
3150	21.10	13.72	7.76	4.25	5600	11.23	4.74	2.62	1.51
3350	21.36	13.89	7.75	4.25	6000	12.00	4.89	2.71	1.55
3550	21.54	14.00	7.70	4.22	6400	12.76	5.01	2.78	1.58
3750	21.65	14.06	7.61	4.17	6800	13.53	5.11	2.84	1.60
3950	21.68	14.07	7.47	4.10	7200	14.29	5.18	2.88	1.61
4150	21.63	14.03	7.29	4.01	7600	15.04	5.23	2.91	1.61
4350	21.52	13.94	7.06	3.89	8000	15.79	5.26	2.93	1.60
					8400	16.54	5.25	2.93	1.58
					8800	17.28	5.23	2.92	1.55
					9200	18.02	5.18	2.90	1.51
					9600	18.76	5.10	2.86	1.46


COOLING FACTORS FOR BLDG. Iib					HEATING FACTORS FOR BLDG. Iib				
CDD	R=2	R=4	R=8	R=16	HDD	R=2	R=4	R=8	R=16
350	10.22	6.30	3.58	2.00	0	0.00	0.00	0.00	0.00
550	13.01	8.11	4.60	2.55	200	0.10	0.02	0.00	0.00
750	14.93	9.34	5.30	2.92	400	0.19	0.04	0.00	0.00
950	16.39	10.29	5.83	3.21	600	0.29	0.06	0.00	0.00
1150	17.57	11.05	6.26	3.44	800	0.38	0.09	0.01	0.00
1350	18.57	11.69	6.62	3.63	1000	0.48	0.12	0.01	0.00
1550	19.42	12.24	6.93	3.80	1200	0.57	0.15	0.02	0.00
1750	20.17	12.72	7.20	3.95	1400	0.67	0.19	0.03	0.00
1950	20.84	13.16	7.45	4.08	1600	0.76	0.22	0.05	0.01
2150	21.44	13.54	7.67	4.20	1800	0.85	0.26	0.06	0.01
2350	21.99	13.90	7.87	4.30	2000	0.95	0.30	0.08	0.02
2550	22.50	14.23	8.05	4.40	2200	1.04	0.35	0.10	0.03
2750	22.97	14.53	8.22	4.49	2400	1.13	0.39	0.12	0.04
2950	23.40	14.81	8.38	4.58	2600	1.22	0.44	0.14	0.05
3150	23.81	15.07	8.52	4.66	2800	1.31	0.48	0.16	0.06
3350	24.19	15.31	8.66	4.73	3000	1.41	0.53	0.19	0.07
3550	24.55	15.55	8.79	4.80	3200	1.50	0.58	0.21	0.09
3750	24.88	15.76	8.92	4.87	3400	1.59	0.63	0.24	0.10
3950	25.21	15.97	9.03	4.93	3600	1.68	0.68	0.27	0.11
4150	25.51	16.17	9.14	4.99	3800	1.76	0.73	0.29	0.13
4350	25.80	16.36	9.25	5.05	4000	1.85	0.78	0.32	0.14
					4200	1.94	0.16	0.35	0.84
					4400	2.03	0.17	0.38	0.89
					4600	2.12	0.19	0.40	0.94
					4800	2.20	0.99	0.43	0.20
					5000	2.29	1.04	0.46	0.22
					5200	2.38	1.10	0.49	0.23
					5400	2.46	1.15	0.52	0.25
					5600	2.55	1.20	0.54	0.26
					5800	2.63	1.25	0.57	0.28
					6000	2.72	1.30	0.59	0.29
					6200	2.80	1.34	0.62	0.30
					6400	2.89	1.39	0.64	0.32
					6600	2.97	1.44	0.66	0.33
					6800	3.05	1.48	0.69	0.34
					7000	3.13	1.52	0.71	0.35
					7200	3.22	1.56	0.72	0.36
					7400	3.30	1.60	0.74	0.37
					7600	3.38	1.64	0.76	0.38
					7800	3.46	1.67	0.77	0.39
					8000	3.54	1.70	0.78	0.39
					8200	3.62	1.73	0.79	0.40
					8400	3.70	1.76	0.80	0.40
					8600	3.78	1.78	0.80	0.41
					8800	3.86	1.80	0.80	0.41
					9000	3.94	1.82	0.80	0.41
					9200	4.01	1.84	0.80	0.41
					9400	4.09	1.85	0.79	0.40

COOLING FACTORS FOR BLDG. III


CDD	R=2	R=4	R=8	R=16
350	11.00	7.06	3.93	2.08
550	13.83	8.78	4.92	2.61
750	15.38	9.72	5.46	2.90
950	16.50	10.39	5.85	3.11
1150	17.38	10.93	6.16	3.28
1350	18.13	11.37	6.42	3.42
1550	18.77	11.75	6.64	3.54
1750	19.34	12.09	6.84	3.65
1950	19.85	12.40	7.02	3.74
2150	20.31	12.68	7.18	3.83
2350	20.74	12.93	7.33	3.91
2550	21.14	13.17	7.47	3.98
2750	21.51	13.39	7.60	4.05
2950	21.85	13.59	7.72	4.12
3150	22.18	13.79	7.83	4.18
3350	22.49	13.97	7.94	4.24
3550	22.79	14.15	8.04	4.29
3750	23.07	14.31	8.14	4.34
3950	23.34	14.47	8.23	4.39
4150	23.59	14.62	8.32	4.44
4250	23.72	14.70	8.36	4.46

ALL HEATING FACTORS FOR BUILDING III = 0.


Cooling factors (Bldg. Ia)




Heating factors (Bldg. Ia)




Cooling factors (Bldg. lb)




Heating factors (Bldg. lb)




Cooling factors (Bldg. Ila)




Heating factors (Bldg. Ila)




Cooling factors (Bldg. IIb)



Heating factors (Bldg. IIb)



Cooling factors (Bldg. III)



ALL HEATING FACTORS FOR BUILDING III = 0.

Appendix E

ENERGY SAVINGS AVAILABLE FROM CHANGING ROOF SURFACE MASS




Figure E-1 – Effect of surface mass on heat gain.

Using data for the same week in May as shown in Fig. 4, the impacts of surface mass on heat gain during hot weather is shown.




Figure E-2 – Effect of surface mass on heat loss.

The impact of roof surface mass on heat loss at night during the same week in May as above are shown in this figure.

Mass is sometimes added to the surface of a roof to act as a ballast for holding the membrane in place. The mass also has an influence on the temperatures experienced by the roof and on the amount of heat that flows through the roof. Surface mass can act as a thermal flywheel by storing up heat during one part of the day and then releasing it during another part of the day.

As an example, consider a roof with no surface mass during a spring day that is warm during the daytime hours and cool during the nighttime hours. During the daytime, the sun shines on the roof and drives heat into the building, while during the night heat flows out of the building because of the cool outdoor air. Now, if surface mass is added to the roof, part of the heat from the sun is stored in the surface mass and does not pass through the roof into the building. Thus the surface mass reduces the amount of heat gained through the roof during the daytime hours. During the nighttime hours, the mass is still somewhat warm because of its stored heat and thus acts to reduce the amount of heat that is lost from the roof during the nighttime hours.

Figures E-1 and E-2 show the total heat gains and losses calculated for roofs using weather data from a week in May in Oak Ridge, Tennessee. During this week, heat would flow into the building during the day (heat gains) and would flow out of the building during the night (heat losses). Adding mass to the surface would result in decreases in both the heat gains and heat losses, with the decreases being greater for greater amounts of mass. Mass is often added as ballast for single ply roof systems. Some typical ballast densities are 10 psf for loose-laid stones and

18–25 psf for paving blocks. The graphs show the changes in heat gains and losses due to mass at both low and high levels of insulation. Generally speaking, the effects of surface mass are considerably smaller than the effect of changing the insulation level. Whether or not these changes in heat gains and losses show up as energy savings depends upon the heat gain and loss picture for the rest of the building and the method of operating the heating and cooling equipment.

Two examples of energy changes due to roof surface mass are given in Figures E-3 and E-4. Figure E-3 shows the cooling energy for a building in Phoenix, where cooling loads are high and heating loads are small. The graph shows the effect of mass at both a high and a low level of surface reflectance. This shows that the effects of surface mass on annual cooling energy is relatively small compared with the effect of changing the surface reflectance. Figure F-4 shows the heating energy for a building in Minot, N.D., where heating loads are high and cooling loads are small. For this case, the energy change due to surface mass is still relatively small, but is not as much different from the effect of surface reflectance as it was for Phoenix. In general, when heating or cooling energies are significant, the changes due to surface mass are usually less than a few percent.




Figure E-3 – Effect of surface mass on cooling energy (Phoenix, AZ).

This figure demonstrates that, although surface mass can have some impact on heat gain for buildings, the overall effect for a whole year is typically small compared to the effect of changing reflectance. The roof R-value is R-2, and the case with mass is for 20 PSF.




Figure E-4 – Effect of surface mass on heating energy (Minot, ND).

The effect of surface mass on heating energy is shown in this figure for a building in Minot, ND. The effect on heating energy is small compared to total loads in a climate with significant heating requirements. The roof R-value is R-2, and the case with mass is for 20 PSF.

Appendix F

NOTES ON THE DEVELOPMENT OF THIS GUIDE

Calculations have been made of the decrease in energy required to cool a building and the increase in energy required to heat a building when the roof's solar reflectance is changed. The DOE 2.1B simulation program was used to make multiple simulations for five building configurations, and the results are summarized in this document to help others estimate the impact of increasing roof reflectance on cooling and heating costs. Descriptions of the cases follow. First a steady-state based overview is presented that illustrates the problem and why more detailed computations are necessary.

STEADY-STATE BASED OVERVIEW

A building collects solar energy when it is exposed to the sun. The amount of solar energy available varies with location and is affected by atmospheric conditions, particularly cloud cover. The portion of available solar energy which ultimately ends up inside a building depends on many factors. A principal part of a building envelope which sees the sun is the roof. This document focuses on how an increase in the solar reflectance of a low slope roof affects that portion of available solar energy which ends up inside the building. Heat entering a building during hours of cooling is a penalty since it increases the amount of heat which must be removed by the cooling system. Heat which enters the building when heating is needed is beneficial, since it reduces the amount the heating system has to provide. Some of the heat entering a building through the roof due to solar effects may occur at times when neither cooling or heating is required, and consequently this energy is neither a cooling penalty nor a heating benefit. Thus, it becomes necessary to determine the heat gain that occurs during times of operation of the cooling and heating systems to make any judgement about the annual influence of solar heat gain through a low slope roof.

A simple estimate of the heat entering a building through a low slope roof can be made using a steady-state calculation. Suppose a building is conditioned continuously with the thermostat kept at the same setting throughout the year. The annual summation of heat which enters the building through the roof can be calculated by the steady-state equation two times, first for the case of a roof that reflects none of the incoming solar energy and secondly for the case of a roof that reflects all of the incoming solar energy. This scenario provides an upper limit on the effect of changing the roof's reflectance. The difference between these two summations is the maximum possible amount of heat which enters the building through the roof due to solar effects. Calculations via this steady-state scenario can be made, but real roofs do not operate in a steady-state mode. It is not feasible to achieve a change in roof solar reflectance from zero to unity. The interiors of buildings are not typically kept at a fixed thermostat set point throughout the year. Therefore, while the steady-state computations provide some insight regarding effects and limiting values, they do not account for real building effects and do not provide any insight into how to separate the annual summation into portions occurring during times of building cooling and heating. Consequently, evaluation of the impact of increasing a low sloped roof's solar reflectance on building energy use requires that a more sophisticated

analysis be made. This is why the DOE 2.1B program was used to make the calculations summarized in this document.

COMPUTATIONAL METHODOLOGY

DOE 2.1B was used in making calculations in order to take into account real building effects and HVAC system operating effects. DOE 2.1B is a versatile, widely used code for modeling a complete building and its HVAC systems. Hour by hour performance is simulated for a user-specified period which can be up to one year in length. Hourly values of key climatic variables are required in an appropriately formatted data file as input to run the program. Typical meteorological year (TMY) weather data files were used for all locations included in the calculations summarized here. The files included available solar energy values for the locations.

DOE 2.1B is structured with several subprograms. Two of these are named LOADS and SYSTEMS. The LOADS subprogram calculates hourly heat gains and heat losses for each component of the building envelope. Gains from specified internal heat sources such as lights, equipment, and people are also included. Space weighting factors are used to convert the predicted gains into loads. All calculations in the LOADS subprogram are made on the basis of a fixed, user-specified inside temperature for each conditioned space within the building. The SYSTEMS subprogram uses the output of the LOADS subprogram, user-specified HVAC system(s), operating schedules, and thermostat set points for conditioned zones to determine hourly values of heat which the cooling coil must remove during periods of cooling and the heating coil must provide during hours when heating is needed. Accumulative sums over the simulation period for each of these quantities are stored and reported as specified. The energy quantities used for the results of this effort were based on the annual summations of the cooling energy that must be removed by the cooling system and of the heating energy that must be added by the heating system.

The scheme was to run the code for a particular building and roof R-value for different values of the roof's solar reflectance. After several simulation runs, it was observed that the annual cooling energy and the annual heating energy reported by the program varied linearly with the roof's solar reflectance. This is a key fact used in presenting the results. This relationship permits use of the results for different increments of solar reflectance and thereby accommodates more universal application than if only one particular change in the roof's solar reflectance were valid. This also means that aging effects can be accommodated if good estimates of how aging alters a roof's solar reflectance can be obtained.

The decrease in annual cooling energy divided by the product of the increase in roof solar reflectance and average daily solar radiation for the location is referred to herein as the cooling factor. Similarly, the increase in annual heating energy divided by the product of the increase in roof solar reflectance and average daily solar radiation for the location is referred to herein as the heating factor.

Use of these results reduces basically to determining the cooling factor and heating factor for specific locations. These factors are multiplied by the average daily solar radiation listed in Appendix A and the estimated increase in the roof's solar reflectance. The result of these two

computations yields, respectively, the cooling energy savings and heating energy penalties for the building and location examined.

CASES EXAMINED

As discussed in relation to the steady-state scenario, reduction in the annual heat flow into a building through the roof caused by increasing its solar reflectance depends on location, roof construction and the magnitude of reflectance increase. The crucial issue is how the reduction in annual heat is divided into a heating penalty and a cooling benefit. All factors that play a role in determining when a building needs heating and when it needs cooling are influential in establishing this division.

In an attempt to cover selected practical situations, five building cases were simulated using DOE 2.1B. It was found after some initial calculations that building size did not significantly affect the results when other conditions were unchanged. Whether or not the building had a plenum space between the conditioned space and the roof and operating schedule and internal loading did influence the computed results. Summary descriptions of the five cases used to generate results for this document are given below.

For all the cases examined, the thermostat settings for cooling and heating were, respectively, 78EF and 72EF. Setback values were 84EF and 63EF for cooling and heating, respectively.

Building Ia:

The building for this case was 25 ft by 60 ft by 10 ft tall, providing a floor area of 1500 sq ft. The load schedule simulated office operation for weekdays only. Occupancy, lights, and equipment were specified for weekdays only. Peak loading included 10 people and 3 W/sq ft for lights and equipment combined. Thermostat setback was used for nighttime and weekends. A suspended ceiling was included with the space between the roof and the suspended ceiling serving as a plenum.

Building Ib:

The building for this case was a two-story structure which simulated a retail store in a shopping mall. The building was not exactly rectangular. Gross floor area was 164,200 sq ft. The average floor-to-floor height was 19 ft. The exposed roof area was 76,240 sq ft. Peak loading on the first floor included 1102 people and 4.26 W/sq ft for lighting. Peak loading on the second floor included 906 people, 4.26 W/sq ft for lights, and 10 kW for equipment. There was a plenum between the conditioned top floor and the roof. A nighttime thermostat was used, but the building operated seven days a week.

Building IIa:

The building for this case consisted of two spaces. The large part was 120 ft by 322 ft by 24 ft tall. An adjacent office building was 32 ft by 66 ft by 12 ft tall. The combination has a gross area of 40,752 sq ft. The load schedule simulated a conditioned warehouse or light assembly plant. Occupancy, lights, and equipment were scheduled for weekdays and for Saturday morning in the office. Peak loading in the office included 16 people and combined

5.36 W/sq ft for lights and equipment. Peak loading in the large building was less with 20 people and a combined 0.9 W/sq ft for lights and equipment. Nighttime and weekend thermostat setback was used. The simulation did not include a plenum.

Building IIb:

The same building used for Building Ia was used in this case except the plenum was removed, internal loading was increased and operating time was extended. Loading schedule simulated office operation throughout the week and half a day on Saturday. No thermostat setback was used. Peak loading included 15 people and a combined 12.5 W/sq ft for equipment and lights.

Building III:

The same building used for Building IIb was used in this case except internal loading and operating schedule were increased more. Loading schedule simulated a restaurant or fastfood operation. Peak loading included 30 people, 2.5 W/sq ft for lights and 50 W/sq ft for equipment. Occupancy, lights and equipment were scheduled for operation throughout the day and into late evening for every day of the week. No thermostat setback was used.

The five cases described above encompass buildings of different size, buildings with and without plenums, different schedules, and a range of internal loading. A few computations were made for Building Ia with the plenum removed. The results agreed almost exactly with computations made for Building IIa for the same locations and same roof R-value.

INTERNAL DISTRIBUTION

1.	R. S. Carlsmith	24-39.	S. D. Samples
2.	P. W. Childs	40.	A. C. Schaffhauser
3.	J. E. Christian	41-50.	T. R. Sharp
4.	G. L. Coleman	51.	R. B. Shelton
5.	G. E. Courville	52.	T. J. Wilbanks
6.	W. Fulkerson	53.	K. E. Wilkes
7.	M. A. Kuliasha	54.	D. W. Yarbrough
8.	P. M. Love	55.	K. H. Zimmerman
9-18.	J. M. MacDonald	56-58.	Laboratory Records
19.	H. A. McLain	59.	Laboratory Records (RC)
20.	D. L. McElroy	60.	ORNL Patent Office
21.	W. R. Mixon	61.	Y-12 Technical Library
22.	D. E. Reichle	62.	Central Research Library
23.	E. T. Rogers	63.	Document Reference Section

EXTERNAL DISTRIBUTION

64. R. L. Alumbaugh, Naval Civil Engineering Lab, Port Hueneme, CA
65. R. W. Anderson, 7090 Tecumseh Lane, Chanhassen, MN
66. F. Arumi-Noe, University of Texas, Austin, TX
67. E. L. Bales, New Jersey Institute of Technology, Newark, NJ
68. C. G. Bankvall, Swedish National Testing Institute, Boras, Sweden
69. M. Bomberg, National Research Council of Canada, Ottawa, Ontario
70. J. J. Boulin, DOE/CE, Washington, DC
71. S. Braun, MIMA, Alexandria, VA
72. J. Carmody, University of Minnesota, Minneapolis, MN
73. W. E. Carson, R-Fax Technologies, Inc., Pomona, CA
74. M. Cunningham, Building Research Association, Private Bag, Porirua, New Zealand
75. J. J. Cuttica, Gas Research Institute, Chicago, IL
76. A. Desjarlais, Thermatest Division of Holometrix, Inc., Cambridge, MA
77. M. Dvorchak, Mobay Chemical Corp., Pittsburgh, PA
78. W. P. Ellis, Standards Consultant, Harleysville, PA
79. F. England, Floyd England and Associates, Waco, TX

80. D. M. Evans, Jr., Steven Winter Associates, Inc., New York, NY
81. P. W. Fairey, III, Florida Solar Energy Center, Cape Canaveral, FL
82. H. A. Fine, 949 Wishbone Circle, Lexington, KY
83. P. Fisette, University of Massachusetts, Amherst, MA
84. W. R. French, Moisture Systems, Incorporated, Houston, TX
85. F. C. Gorham, Roofing Services, Incorporated, Springfield, VA
86. J. Greko, Duro-Last Roofing, Inc., Saginaw, MI
- 87-96. E. I. Griggs, Tennessee Technological University, Cookeville, TN
97. J. R. Hagan, Jim Walter Research, St. Petersburg, FL
98. R. O. Hinckley, University of Southwestern Louisiana, Lafayette, LA
99. B. Howard, NAHB National Research Center, Upper Marlboro, MD
100. W. R. Huntley, 12422 Union Road, Knoxville, TN
101. B. Hyma, Energy Saver Imports, Inc., Broomfield, CO
102. J. L. Ius, Tyndall Air Force Base, FL
103. E. Johannes, EFCG, U.S. Department of Energy, Bonneville Power Administration, Portland, OR
104. R. E. Jones, DOE, Washington, DC
105. J. P. Kalt, Harvard University, Cambridge, MA
106. W. A. Kim, Rohm and Haas Co., Spring House, PA
107. C. J. Korhonen, CRREL, Hanover, NH
108. M. Krarti, Steven Winter Associates, Inc., Norwalk, CT
109. R. J. Kudder, Rath's, Rath's & Johnson, Inc., Willowbrook, IL
110. R. A. LaCrosse, National Roofing Contractors Assn., Rosemont, IL
111. E. Leger, P.O. Box 549, New Boston, NH
112. R. A. Lucas, Tremco, Lexington, MA
113. R. H. Marcy, Headquarters, Air Force Engineering & Services, Tyndall AFB, FL
114. P. C. Martin, Manville Sales Corporation, Denver, CO
115. R. F. Martin, Roof Maintenance Systems, Farmingdale, NJ
116. M. McBride, Owens-Corning Fiberglas, Granville, OH
117. D. McGuire, Regal Industries, Crothersville, IN
118. C. R. McIntyre, Hickson Corporation, Orrville, OH
119. M. McManus, University of Tennessee, Knoxville, TN
120. K. Mentzer, MIMA, 1420 King Street, Alexandria, VA
121. G. Miller, Jim Walter Research Corp., St. Petersburg, FL
122. M. Modera, Lawrence Berkeley Laboratory, Berkeley, CA
123. F. O. Moore, Jr., Koppers Industry, 440 College Park Drive, Monroeville, PA
124. D. E. Morrison, Michigan State University, East Lansing, MI
125. J. R. Mumaw, Owens-Corning Fiberglas, Granville, OH
126. B. Nelson, Minnesota Dept. of Public Service, Energy Division, St. Paul, MN
127. N. Nisson, Energy Design Update, Ansonia Station, New York, NY
128. E. Nowman, Fi-Foil Company, Inc., Auburndale, FL

129. R. L. Perrine, University of California, Los Angeles, CA
130. W. Prichett, Chattanooga State Tech Community College, Chattanooga, TN
131. D. Prowler, 2302 Locust Street, Philadelphia, PA
132. D. E. Richards, Owens-Corning Fiberglas, Toledo, OH
133. W. J. Rossiter, NIST, Gaithersburg, MD
134. J. A. Roux, University of Mississippi, University, MS
135. W. W. Seaton, ASHRAE, Atlanta, GA
136. G. Sebestyen, International Council for Building Research Studies and Documentation, P.O. Box 20704, 3001 JA Rotterdam, The Netherlands
137. S. Selkowitz, Lawrence Berkeley Laboratory, Berkeley, CA
138. A. Skinner, Roofing Service Associates, Knoxville, TN
139. J. A. Smith, DOE/CE, Washington, DC
140. M. K. Snyder, 9107 Outlook Drive, Overland Park, KS
141. L. G. Spielvogel, Wyncote House, Wyncote, PA
142. R. Sterling, University of Minnesota, Minneapolis, MN
143. E. Story, Insultray, Oak Harbor, WA
144. R. Sullivan, National Center for Appropriate Technology, Butte, MT
145. S. Tagore, Department of Energy, Washington, DC
146. A. TenWolde, U.S. Dept. of Agriculture, Forest Products Lab, Madison, WI
147. S. Tewes, University of Illinois at Urbana, Champaign, IL
148. S. Theimer, CAREIRS/ASI, Arlington, VA
149. J. G. Thimmig, Metal Building Manufacturers Assoc., Inc., Cleveland, OH
150. G. A. Tsongas, Portland State University, Portland, OR
151. A. Tuluca, Steven Winter Associates, Norwalk, CT
152. R. P. Tye, Thermatest Division of Holometrix, Inc., Cambridge, MA
153. C. R. Vander Linden, Vander Linden & Associates, Littleton, CO
154. M. G. Van Geem, Construction Technology Laboratories, Inc., Skokie, IL
155. J. R. Warner, ACEC Research and Management Foundation, Washington, DC
156. W. J. Woodring, GAF Corp., Wayne, NJ
157. Office, Assistant Manager, Energy Research and Development, DOE/ORO, Oak Ridge, TN
- 158-167. Office of Scientific and Technical Information, U.S. Department of Energy, Oak Ridge, TN