# CHAPTER 3 USE AND OCCUPANCY CLASSIFICATION

# SECTION 301 GENERAL

**301.1 Scope.** The provisions of this chapter shall control the classification of all buildings and structures as to use and occupancy.

#### SECTION 302 CLASSIFICATION

**302.1 General.** Structures or portions of structures shall be classified with respect to occupancy in one or more of the groups listed below. A room or space that is intended to be occupied at different times for different purposes shall comply with all of the requirements that are applicable to each of the purposes for which the room or space will be occupied. Structures with multiple occupancies or uses shall comply with Section 508. Where a structure is proposed for a purpose that is not specifically provided for in this code, such structure shall be classified in the group that the occupancy most nearly resembles, according to the fire safety and relative hazard involved.

- 1. Assembly (see Section 303): Groups A-1, A-2, A-3, A-4 and A-5
- 2. Business (see Section 304): Group B
- 3. Educational (see Section 305): Group E
- 4. Factory and Industrial (see Section 306): Groups F-1 and F-2
- 5. High Hazard (see Section 307): Groups H-1, H-2, H-3, H-4 and H-5
- 6. Institutional (see Section 308): Groups I-1, I-2, I-3 and I-4
- 7. Mercantile (see Section 309): Group M
- 8. Residential (see Section 310): Groups R-1, R-2, R-3 and R-4
- 9. Special residence for assisted self-preservation (see Appendix SR): Groups SR-1, SR-2, SR-3 and SR-4
- 10. Storage (see Section 311): Groups S-1 and S-2
- 11. Utility and Miscellaneous (see Section 312): Group U

# SECTION 303 ASSEMBLY GROUP A

**303.1** Assembly Group A. Assembly Group A occupancy includes, among others, the use of a building or structure, or a portion thereof, for the gathering of persons for purposes such

as civic, social or religious functions; recreation, food or drink consumption; or awaiting transportation.

# **Exceptions:**

- 1. A building or tenant space used for assembly purposes with an occupant load of less than 50 persons shall be classified as a Group B occupancy.
- 2. A room or space used for assembly purposes with an occupant load of less than 50 persons and accessory to another occupancy shall be classified as a Group B occupancy or as part of that occupancy.
- 3. A room or space used for assembly purposes that is less than 750 square feet (70 m<sup>2</sup>) in area and is accessory to another occupancy shall be classified as a Group B occupancy or as part of that occupancy.

Assembly occupancies shall include the following:

A-1 Assembly uses, usually with fixed seating, intended for the production and viewing of the performing arts or motion pictures including, but not limited to:

> Motion picture theaters Symphony and concert halls Television and radio studios admitting an audience Theaters

A-2 Assembly uses intended for food and/or drink consumption including, but not limited to:

> Banquet halls Night clubs Restaurants Taverns and bars

A-3 Assembly uses intended for worship, recreation or amusement and other assembly uses not classified elsewhere in Group A including, but not limited to:

> Amusement arcades Art galleries Bowling alleys Places of religious worship Community halls Courtrooms Dance halls (not including food or drink consumption) Exhibition halls Funeral parlors Gymnasiums (without spectator seating) Indoor swimming pools (without spectator seating) Indoor tennis courts (without spectator seating) Lecture halls Libraries Museums

T

Waiting areas in transportation terminals Pool and billiard parlors

A-4 Assembly uses intended for viewing of indoor sporting events and activities with spectator seating including, but not limited to:

> Arenas Skating rinks Swimming pools Tennis courts

A-5 Assembly uses intended for participation in or viewing outdoor activities including, but not limited to:

Amusement park structures Bleachers Grandstands Stadiums

# SECTION 304 BUSINESS GROUP B

**ORS 441.060** is not part of this code but is reproduced here for the reader's convenience:

441.060 Inspections; approval of plans and specifications; rules; fees.

(1) The Department of Human Services shall make or cause to be made such inspections as it may deem necessary.

(2) The Department of Human Services may prescribe by rule that any licensee or prospective applicant desiring to make specified types of alteration or addition to its facilities or to construct new facilities shall, before commencing such alteration, addition or new construction, either prior to or after receiving a certificate of need pursuant to ORS 442.340 (1987 Replacement Part), if required, submit plans and specifications therefor to the department for preliminary inspection and approval or recommendations with respect to compliance with the rules authorized by ORS 441.055 and 443.420 and for compliance with National Fire Protection Association standards when the facility is also to be Medicare or Medicaid certified. The department may require by rule payment of a fee for project review services at a variable rate, dependent on total project cost. For health care facilities, the department shall develop a review fee schedule as minimally necessary to support the staffing level and expenses required to administer the program. The fee for project review of residential care facilities shall equal two-thirds that required of health care facilities. The department may also conduct an on-site review of projects as a prerequisite to licensure of new facilities, major renovations and expansions.

The department shall, at least annually, with the advice of facilities covered by this review, present proposed rule changes regarding facility design and construction to such agencies for their consideration. The department shall also publish a state submissions guide for health and residential care facility projects and advise project sponsors of applicable requirements of federal, state and local regulatory agencies. [Amended by 1965 c.352 §2; 1971 c.730 §14; 1973 c.840 §10; 1985 c.747 §29; 1987 c.428 §11; 1987 c.660 §23; 2001 c.104 §178; 2001 c.900 §169]

**304.1 Business Group B.** Business Group B occupancy includes, among others, the use of a building or structure, or a portion thereof, for office, professional or service-type transac-

tions, including storage of records and accounts. Business occupancies shall include, but not be limited to, the following:

Airport traffic control towers Animal hospitals, kennels and pounds Banks Barber and beauty shops Car wash Civic administration Clinic—outpatient (see definition in Section 304.1.1) Dry cleaning and laundries: pick-up and delivery stations and self-service Educational occupancies for students above the 12th grade L Electronic data processing Laboratories: testing and research Motor vehicle showrooms Post offices Print shops Professional services (architects, attorneys, dentists, physicians, engineers, etc.) Radio and television stations Telephone exchanges

Training and skill development not within a school or academic program

**304.1.1 Definitions.** The following words and terms shall, for the purposes of this section and as used elsewhere in this code, have the meanings shown herein.

**CLINIC-OUTPATIENT.** A medical office or facility serving patients who are capable of self-preservation, or not more than five patients who may be incapable of self-preservation (for facilities with more than five patients who may be incapable of self-preservation, see Ambulatory Health Care Facilities in Section 308.3).

**304.2 Lockup facilities.** Buildings containing lockup facilities, as defined in ORS 169.005(4), shall comply with the following provisions:

- 1. Areas containing lockup facilities shall be separated from other rooms, spaces or areas by an approved smoke barrier (see Section 909.5).
- 2. The smoke control zone in which the lockup cells are located shall be provided with an automatic fire sprinkler system complying with Chapter 9 requirements for Group I-3 occupancies.
- 3. The smoke control zone in which the lockup area is located shall be provided with an automatic smoke detection system installed in accordance with the *Fire Code* Group I-3 occupancies.
- 4. The combined occupant load of the holding cells shall not exceed five.

**ORS 169.005(5)** is not part of this code but is reproduced here for the reader's convenience:

**169.005(5)** "Lockup" means a facility for the temporary detention of arrested persons held for up to 36 hours, excluding holidays, Saturdays and Sundays, but the period in lockup shall not exceed 96 hours after booking.

# SECTION 305 EDUCATIONAL GROUP E

**305.1 Educational Group E.** Educational Group E occupancy includes, among others, the use of a building or structure, or a portion thereof, by six or more persons at any one time for educational purposes through the 12th grade. Religious educational rooms and religious auditoriums, which are accessory to places of religious worship in accordance with Section 508.3.1 and have occupant loads of less than 100, shall be classified as A-3 occupancies.

**305.2 Day care.** The use of a building or structure, or portion thereof, for educational, supervision or personal care services for more than five children older than  $2^{1}/_{2}$  years of age, shall be classified as a Group E occupancy.

# SECTION 306 FACTORY GROUP F

**306.1 Factory Industrial Group F.** Factory Industrial Group F occupancy includes, among others, the use of a building or structure, or a portion thereof, for assembling, disassembling, fabricating, finishing, manufacturing, packaging, repair or processing operations that are not classified as a Group H hazardous or Group S storage occupancy.

**306.2 Factory Industrial F-1 Moderate-hazard Occupancy.** Factory industrial uses which are not classified as Factory Industrial F-2 Low Hazard shall be classified as F-1 Moderate Hazard and shall include, but not be limited to, the following:

Aircraft Appliances Athletic equipment Automobiles and other motor vehicles Bakeries Beverages; over 16-percent alcohol content Bicycles **Boats** Brooms or brushes **Business** machines Cameras and photo equipment Canvas or similar fabric Carpets and rugs (includes cleaning) Clothing Construction and agricultural machinery Disinfectants Dry cleaning and dyeing Electric generation plants Electronics Engines (including rebuilding) Food processing Furniture Hemp products Jute products Laundries Leather products Machinery Metals Millwork (sash & door) Motion pictures and television filming (without spectators) Musical instruments

11

Optical goods Paper mills or products Photographic film Plastic products Printing or publishing Recreational vehicles Refuse incineration Shoes Soaps and detergents Textiles Tobacco Trailers Upholstering Wood; distillation Woodworking (cabinet)

**306.3 Factory Industrial F-2 Low-hazard Occupancy.** Factory industrial uses that involve the fabrication or manufacturing of noncombustible materials which during finishing, packing or processing do not involve a significant fire hazard shall be classified as F-2 occupancies and shall include, but not be limited to, the following:

Beverages; up to and including 16-percent alcohol content || Brick and masonry Ceramic products Foundries Glass products Gypsum Ice Metal products (fabrication and assembly) Wood barrel and bottled wine aging facilities in wineries

# SECTION 307 HIGH-HAZARD GROUP H

**[F] 307.1 High-hazard Group H.** High-hazard Group H occupancy includes, among others, the use of a building or structure, or a portion thereof, that involves the manufacturing, processing, generation or storage of materials that constitute a physical or health hazard in quantities in excess of those allowed in control areas constructed and located as required in Section 414. Hazardous uses are classified in Groups H-1, H-2, H-3, H-4 and H-5 and shall be in accordance with this section, the requirements of Section 415 and the *Fire Code*.

**Exceptions:** The following shall not be classified in Group H, but shall be classified in the occupancy that they most nearly resemble:

- 1. Buildings and structures that contain not more than the maximum allowable quantities per control area of hazardous materials as shown in Tables 307.1(1) and 307.1(2), provided that such buildings are maintained in accordance with the *Fire Code*.
- 2. Buildings utilizing control areas in accordance with Section 414.2 that contain not more than the maximum allowable quantities per control area of hazardous materials as shown in Tables 307.1(1) and 307.1(2).
- 3. Buildings and structures occupied for the application of flammable finishes, provided that such build-

ings or areas conform to the requirements of Section 416 and the *Fire Code*.

- 4. Wholesale and retail sales and storage of flammable and combustible liquids in mercantile occupancies conforming to the *Fire Code*.
- 5. Closed piping system containing flammable or combustible liquids or gases utilized for the operation of machinery or equipment.
- 6. Cleaning establishments that utilize combustible liquid solvents having a flash point of 140°F (60°C) or higher in closed systems employing equipment listed by an approved testing agency, provided that this occupancy is separated from all other areas of the building by 1-hour fire barriers or 1-hour horizontal assemblies or both.
- 7. Cleaning establishments that utilize a liquid solvent having a flash point at or above 200°F (93°C).
- 8. Liquor stores and distributors without bulk storage.
- 9. Refrigeration systems.
- 10. The storage or utilization of materials for agricultural purposes on the premises.
- 11. Stationary batteries utilized for facility emergency power, uninterrupted power supply or telecommunication facilities, provided that the batteries are provided with safety venting caps and ventilation is provided in accordance with the *Mechanical Code*.
- 12. Corrosives shall not include personal or household products in their original packaging used in retail display or commonly used building materials.
- 13. Buildings and structures occupied for aerosol storage shall be classified as Group S-1, provided that such buildings conform to the requirements of the *Fire Code*.
- 14. Display and storage of nonflammable solid and nonflammable or noncombustible liquid hazardous materials in quantities not exceeding the maximum allowable quantity per control area in Group M or S occupancies complying with Section 414.2.5.
- 15. The storage of black powder, smokeless propellant and small arms primers in Groups M and R-3 and special industrial explosive devices in Groups B, F, M and S, provided such storage conforms to the quantity limits and requirements prescribed in the *Fire Code*.

**307.1.1 Hazardous materials.** Hazardous materials in any quantity shall conform to the requirements of this code, including Section 414, and the *Fire Code*.

**307.1.2 Storage of Class 1.4G (Class C Common) fireworks.** A permanent building used for the temporary storage of 1.4G (Class C) fireworks as authorized by a retail sales permit under ORS 480.127 may be classified as either a Group M, Group S-1 or a detached Group U occupancy provided:

1. The total amount of 1.4G retail fireworks is less than 5,000 pounds (2268 kg) gross weight; or

2. When the building is protected by an approved automatic sprinkler system and the amount of 1.4G retail fireworks is less than 10,000 pounds (4636 kg) gross weight.

**[F] 307.2 Definitions.** The following words and terms shall, for the purposes of this section and as used elsewhere in this code, have the meanings shown herein.

**AEROSOL.** A product that is dispensed from an aerosol container by a propellant.

Aerosol products shall be classified by means of the calculation of their chemical heats of combustion and shall be designated Level 1, 2 or 3.

**Level 1 aerosol products.** Those with a total chemical heat of combustion that is less than or equal to 8,600 British thermal units per pound (Btu/lb) (20 kJ/g).

**Level 2 aerosol products.** Those with a total chemical heat of combustion that is greater than 8,600 Btu/lb (20 kJ/g), but less than or equal to 13,000 Btu/lb (30 kJ/g).

**Level 3 aerosol products.** Those with a total chemical heat combustion that is greater than 13,000 Btu/lb (30 kJ/g).

**AEROSOL CONTAINER.** A metal can or a glass or plastic bottle designed to dispense an aerosol. Metal cans shall be limited to a maximum size of 33.8 fluid ounces (1,000 ml). Glass or plastic bottles shall be limited to a maximum size of 4 fluid ounces (118 ml).

**BALED COTTON.** A natural seed fiber wrapped in and secured with industry accepted materials, usually consisting of burlap, woven polypropylene, polyethylene or cotton or sheet polyethylene, and secured with steel, synthetic or wire bands or wire; also includes linters (lint removed from the cottonseed) and motes (residual materials from the ginning process).

**BALED COTTON, DENSELY PACKED.** Cotton made into banded bales with a packing density of at least 22 pounds per cubic foot ( $360 \text{ kg/m}^3$ ), and dimensions complying with the following: a length of 55 inches ( $1397 \pm 20 \text{ mm}$ ), a width of 21 inches ( $533.4 \pm 20 \text{ mm}$ ) and a height of 27.6 to 35.4 inches (701 to 899 mm).

**BARRICADE.** A structure that consists of a combination of walls, floor and roof, which is designed to withstand the rapid release of energy in an explosion and which is fully confined, partially vented or fully vented; or other effective method of shielding from explosive materials by a natural or artificial barrier.

**Artificial barricade.** An artificial mound or revetment a minimum thickness of 3 feet (914 mm).

**Natural barricade.** Natural features of the ground, such as hills, or timber of sufficient density that the surrounding exposures that require protection cannot be seen from the magazine or building containing explosives when the trees are bare of leaves.

**BOILING POINT.** The temperature at which the vapor pressure of a liquid equals the atmospheric pressure of 14.7 pounds per square inch (psi) (101 kPa) gage or 760 mm of mercury. Where an accurate boiling point is unavailable for the material in question, or for mixtures which do not have a

constant boiling point, for the purposes of this classification, the 20-percent evaporated point of a distillation performed in accordance with ASTM D 86 shall be used as the boiling point of the liquid.

**CLOSED SYSTEM.** The use of a solid or liquid hazardous material involving a closed vessel or system that remains closed during normal operations where vapors emitted by the product are not liberated outside of the vessel or system and the product is not exposed to the atmosphere during normal operations; and all uses of compressed gases. Examples of closed systems for solids and liquids include product conveyed through a piping system into a closed vessel, system or piece of equipment.

**COMBUSTIBLE DUST.** Finely divided solid material that is 420 microns or less in diameter and which, when dispersed in air in the proper proportions, could be ignited by a flame, spark or other source of ignition. Combustible dust will pass through a U.S. No. 40 standard sieve.

COMBUSTIBLE FIBERS. Readily ignitable and
 free-burning materials in a fibrous or shredded form, such as cocoa fiber, cloth, cotton, excelsior, hay, hemp, henequen, istle, jute, kapok, oakum, rags, sisal, Spanish moss, straw, tow, wastepaper, certain synthetic fibers or other like materials. This definition does not include densely packed baled cotton.

**COMBUSTIBLE LIQUID.** A liquid having a closed cup flash point at or above 100°F (38°C). Combustible liquids shall be subdivided as follows:

**Class II.** Liquids having a closed cup flash point at or above 100°F (38°C) and below 140°F (60°C).

**Class IIIA.** Liquids having a closed cup flash point at or above 140°F (60°C) and below 200°F (93°C).

**Class IIIB.** Liquids having a closed cup flash point at or above 200°F (93°C).

The category of combustible liquids does not include compressed gases or cryogenic fluids.

**COMPRESSED GAS.** A material, or mixture of materials which:

- 1. Is a gas at 68°F (20°C) or less at 14.7 pounds per square inch atmosphere (psia) (101 kPa) of pressure; and
- 2. Has a boiling point of 68°F (20°C) or less at 14.7 psia (101 kPa) which is either liquefied, nonliquefied or in solution, except those gases which have no other health- or physical-hazard properties are not considered to be compressed until the pressure in the packaging exceeds 41 psia (282 kPa) at 68°F (20°C).

The states of a compressed gas are categorized as follows:

1. Nonliquefied compressed gases are gases, other than those in solution, which are in a packaging under the charged pressure and are entirely gaseous at a temperature of  $68^{\circ}F$  (20°C).

- 2. Liquefied compressed gases are gases that, in a packaging under the charged pressure, are partially liquid at a temperature of 68°F (20°C).
- 3. Compressed gases in solution are nonliquefied gases that are dissolved in a solvent.
- 4. Compressed gas mixtures consist of a mixture of two or more compressed gases contained in a packaging, the hazard properties of which are represented by the properties of the mixture as a whole.

**CONTROL AREA.** Spaces within a building where quantities of hazardous materials not exceeding the maximum allowable quantities per control area are stored, dispensed, used or handled. See also the definition of "Outdoor control area" in the *Fire Code*.

**CORROSIVE.** A chemical that causes visible destruction of, or irreversible alterations in, living tissue by chemical action at the point of contact. A chemical shall be considered corrosive if, when tested on the intact skin of albino rabbits by the method described in DOTn 49 CFR, Part 173.137, such a chemical destroys or changes irreversibly the structure of the tissue at the point of contact following an exposure period of 4 hours. This term does not refer to action on inanimate surfaces.

**CRYOGENIC FLUID.** A liquid having a boiling point lower than -150°F (-101°C) at 14.7 pounds per square inch atmosphere (psia) (an absolute pressure of 101 kPa).

**DAY BOX.** A portable magazine designed to hold explosive materials constructed in accordance with the requirements for a Type 3 magazine as defined and classified in Chapter 33 of the *Fire Code*.

**DEFLAGRATION.** An exothermic reaction, such as the extremely rapid oxidation of a flammable dust or vapor in air, in which the reaction progresses through the unburned material at a rate less than the velocity of sound. A deflagration can have an explosive effect.

**DETACHED BUILDING.** A separate single-story building, without a basement or crawl space, used for the storage or use of hazardous materials and located an approved distance from all structures.

**DETONATION.** An exothermic reaction characterized by the presence of a shock wave in the material which establishes and maintains the reaction. The reaction zone progresses through the material at a rate greater than the velocity of sound. The principal heating mechanism is one of shock compression. Detonations have an explosive effect.

**DISPENSING.** The pouring or transferring of any material from a container, tank or similar vessel, whereby vapors, dusts, fumes, mists or gases are liberated to the atmosphere.

30

MA	XIMUM ALLOW	'ABLE QUANTIT	Y PER CONTR	[F] TABLE OL AREA OF H	E 307.1(1) AZARDOUS M	ATERIALS PO	SING A PHYSIC	AL HAZARD <sup>a, j</sup>	, m, n, p	
		GROUP WHEN		<b>STORAGE<sup>b</sup></b>		ÎSU	-CLOSED SYSTEM	٩Sb	USE-OPEN	SYSTEMS <sup>b</sup>
MATERIAL	CLASS	THE MAXIMUM ALLOWABLE QUANTITY IS EXCEEDED	Solid pounds (cubic feet)	Liquid gallons (pounds)	Gas (cubic feet at NTP)	Solid pounds (cubic feet)	Liquid gallons (pounds)	Gas (cubic feet at NTP)	Solid pounds (cubic feet)	Liquid gallons (pounds)
Combustible liquid <sup>e, i</sup>	II IIIA IIIB	H-2 or H-3 H-2 or H-3 N/A	N/A	120 <sup>d, e</sup> 330 <sup>d, e</sup> 13,200 <sup>e, f</sup>	N/A	N/A	$120^{\rm d}$ $330^{\rm d}$ $13,200^{\rm f}$	N/A	N/A	$30^{\rm d} \\ 80^{\rm d} \\ 3,300^{\rm f}$
Combustible fiber	Loose baled <sup>o</sup>	Н-3	(100) (1,000)	N/A	N/A	(100) (1,000)	N/A	N/A	(20) (200)	N/A
Consumer fireworks (Class C, Common)	1.4G	Н-3	125 <sup>d, e, 1</sup>	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Cryogenics flammable	N/A	H-2	N/A	45 <sup>d</sup>	N/A	N/A	45 <sup>d</sup>	N/A	N/A	$10^{d}$
Cryogenics, oxidizing	N/A	H-3	N/A	45 <sup>d</sup>	N/A	N/A	45 <sup>d</sup>	N/A	N/A	$10^{d}$
	Division 1.1	H-1	1e. e	(1) <sup>e, g</sup>	N/A	$0.25^{g}$	$(0.25)^{g}$	N/A	0.25 <sup>g</sup>	$(0.25)^{g}$
	Division 1.2 Division 1.3	H-1 H-1 or 2	τς, σ, α δ, α	(1) <sup>e, g</sup>	N/A N/A	$0.25^{g}$	$(0.25)^{g}_{g}$	N/A N/A	$0.25^{g}$	$(0.25)^{g}_{g}$
Explosives	Division 1.4	H-1 01 2 H-3	50 <sup>e, g</sup>	$(50)^{6, g}$	N/A	$50^{\circ}$	$(50)^{g}$	N/A	N/A	N/A
4	Division 1.4G	H-3	125 <sup>d, e, 1</sup>	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Division 1.5 Division 1.6	H-1 H-1	1e, g 1d, e, g	(1) <sup>e, g</sup> N/A	N/A N/A	0.25 <sup>g</sup> N/A	(0.25) <sup>g</sup> N/A	N/A N/A	0.25 <sup>g</sup> N/A	(0.25) <sup>g</sup> N/A
Flammable gas	Gaseous liquefied	H-2	N/A	N/A 30 <sup>d, e</sup>	1,000 <sup>d, e</sup> N/A	N/A	N/A 30 <sup>d, e</sup>	1,000 <sup>d, e</sup> N/A	N/A	N/A
${ m Flammable}$ liquid $^{ m c}$	1A 1B and 1C	H-2 or H-3	N/A	30 <sup>d, e</sup> 120 <sup>d, e</sup>	N/A	N/A	$30^{\rm d}$ $120^{\rm d}$	N/A	N/A	$10^{\rm d}$ $30^{\rm d}$
Combination flammable liquid (1A, 1B, 1C)	N/A	H-2 or H-3	N/A	120 <sup>d, e, h</sup>	N/A	N/A	120 <sup>d, h</sup>	N/A	N/A	30 <sup>d, h</sup>
Flammable solid	N/A	H-3	125 <sup>d, e</sup>	N/A	N/A	125 <sup>d</sup>	N/A	N/A	25 <sup>d</sup>	N/A
Organic peroxide	OD I II II S X	H-1 H-2 H-3 H-3 N/A	1e. g 5d. e 50d. e NL	(1) <sup>e. g</sup> (5) <sup>d. e</sup> (50) <sup>d. e</sup> (125) <sup>d. e</sup> NL	N/A N/A N/A N/A N/A N/A	0.25 <sup>g</sup> 1 <sup>d</sup> 50 <sup>d</sup> N/L	(0.25) <sup>g</sup> (1) (50) <sup>d</sup> (125) <sup>d</sup> N/L	N/A N/A N/A N/A N/A	0.25 <sup>g</sup> 1 <sup>d</sup> 25 <sup>d</sup> NL	$(0.25)^{g}$ (1) <sup>d</sup> (10) <sup>d</sup> (25) <sup>d</sup> NL
	>	N/A	NL	NL	NA	INL	INL	N/A	NL	NL
	4 k	H-1 H-2 or H-3	1e, g 10d, e	(1) <sup>e, g</sup> (10) <sup>d, e</sup>	N/A N/A	$0.25^{g}$	$(0.25)^{g}_{(2)^{d}}$	N/A N/A	$0.25^{g}$	$(0.25)^{g}$
Oxidizer	- 7 - 1	H-3 N/A	250 <sup>d, e</sup> 4,000 <sup>e,f</sup>	(250) <sup>d, e</sup> (4,000) <sup>e,f</sup>	N/A	$250^{d}$ 4,000 <sup>f</sup>	$(250)^{d}$ (4,000) <sup>f</sup>	N/A N/A	$50^{ m d}$ $1,000^{ m f}$	$(50)^{d}$ (1,000) <sup>f</sup>
Oxidizing gas	Gaseous liquefied	Н-3	N/A N/A	N/A 15 <sup>d, e</sup>	1,500 <sup>d, e</sup> N/A	N/A N/A	N/A 15 <sup>d, e</sup>	1,500 <sup>d, e</sup> N/A	N/A N/A	N/A N/A

(continued)

		<b>GROUP WHEN</b>		<b>STORAGE<sup>b</sup></b>		USE	E-CLOSED SYSTEM	۸S <sup>b</sup>	<b>USE-OPEN</b>	SYSTEMS <sup>b</sup>
MATERIAL	CLASS	THE MAXIMUM ALLOWABLE QUANTITY IS EXCEEDED	Solid pounds (cubic feet)	Liquid gallons (pounds)	Gas (cubic feet at NTP)	Solid pounds (cubic feet)	Liquid gallons (pounds)	Gas (cubic feet at NTP)	Solid pounds (cubic feet)	Liquid gallons (pounds)
Pyrophoric material	N/A	H-2	4 <sup>e, g</sup>	(4) <sup>e, g</sup>	50 <sup>e, g</sup>	<u>ac</u>	(1) <sup>g</sup>	10 <sup>e, g</sup>	0	0
Unstable (reactive)	4 ω Ο –	H-1 H-1 or H-2 H-3 N/A	1 e. g 5d. e NL	$(1)^{e. g}$ $(5)^{d. e}$ $(50)^{d. e}$ NL	10 <sup>d, g</sup> 50 <sup>d, e</sup> 250 <sup>d, e</sup>	0.25 <sup>g</sup> 1 <sup>d</sup> 50 <sup>d</sup> NL	(0.25) <sup>g</sup> (1) (50) <sup>d</sup> N/L	2 <sup>e, g</sup> 10 <sup>d, e</sup> NL	$\begin{array}{c} 0.25^{g} \\ 1^{d} \\ 10^{d} \\ \mathrm{NL} \end{array}$	$(0.25)^{g}$ $(1)^{d}$ $(10)^{d}$ NL
Water reactive	ω c) –	H-2 H-3 N/A	5 <sup>d, e</sup> 50 <sup>d, e</sup> NL	(5) <sup>d, e</sup> (50) <sup>d, e</sup> NL	N/A N/A N/A	5 <sup>d</sup> S <sup>d</sup>	(5) <sup>d</sup> NL	N/A N/A N/A	1 <sup>d</sup> NL	(1) <sup>d</sup> (10) <sup>d</sup> NL
For SI: 1 cubic foot = $0.023 \text{ m}^3$ , NL = Not Limited; N/A = Not Ap a. For use of control areas, see See b. The aggregate quantity in use a c. The quantities of alcoholic bevel occupancies, the quantities of m being flammable, shall not be li d. Maximum allowable quantities is	1 pound = $0.454$ plicable; UD = $U$ ction 414.2. nd storage shall 1 ages in retail and dicines, foodstul mited, provided hall be increased mulativelv.	kg, 1 gallon = 3.78 Inclassified Detona not exceed the quar wholesale sales occ ffs, consumer or ind that such materials 100 percent in buil	85 L. able ntity listed for stu cupancies shall n lustrial products, : are packaged in dings equipped th	orage. ot be limited provid and cosmetics cont individual contain 'rroughout with an a	ling the liquids an taining not more ters not exceedin utomatic sprinkl	re packaged in indi than 50 percent by ig 1.3 gallons. ler system in accor	vidual containers n volume of water-m dance with Section	ot exceeding 1.3 iiscible liquids w 903.3.1.1. Wher	gallons. In retail ar ith the remainder o e Note e also applic	d wholesale sales f the solutions not s, the increase for
e. Maximum allowable quantities both notes shall be applied accu	shall be increased mulatively.	1 100 percent when	1 stored in approv	/ed storage cabinets	s, day boxes, gas nkler system in :	cabinets, exhaust	ed enclosures or saf	fety cans. Where	Note d also applie	s, the increase for
<ul> <li>a. The permittee operations of an analysis of the permittee only in buildings equal h. Containing not more than the maximum i. Inside a building, the maximum permittees in parenthesis indica between a maximum contractive of 200 contractions.</li> </ul>	ipped throughou laximum allowat (capacity of a co te quantity units	t with an automatic ble quantity per con mbustible liquid st in parenthesis at th	c sprinkler syster itrol area of Clas orage system the le head of each c	n in accordance wi is IA, IB or IC flar it is connected to a olumn.	ith Section 903.3 mmable liquids. fuel-oil piping s	3.1.1. system shall be 66	0 gallons provided	such system con	mplies with the Fin	e Code.

Net weight of the pyrotechnic composition of the fireworks. Where the net weight of the pyrotechnic composition of the fireworks is not known, 25 percent of the gross weight of the fireworks, including packaging.

n. For storage and display quantities in Group M and storage quantities in Group S occupancies complying with Section 414.2.5, see Tables 414.2.5(1) and 414.2.5(2)

Densely packed baled cotton that complies with the packing requirements of ISO 8115 shall not be included in this material class.

p. The following shall not be included in determining the maximum allowable quantities:

1. Liquid or gaseous fuel in fuel tanks on vehicles.

2. Liquid or gaseous fuel in fuel tanks on motorized equipment operated in accordance with this code.

4. Liquid fuels in piping systems and fixed appliances regulated by the Mechanical Code. 3. Gaseous fuels in piping systems and fixed appliances regulated by the Fuel Gas Code.

m. For gallons of liquids, divide the amount in pounds by 10 in accordance with Section 2703.1.2 of the Fire Code.

ers and the manner of storage shall be approved.

shall be used.

ö

			ER CONTROL A	REA OF HAZA	RDOUS MATER	TAL PUSING A	<b>NEALIN NAZA</b>	RD-, -, -, ,
		STORAGE <sup>d</sup>		USE	-CLOSED SYSTE	MS <sup>d</sup>	USE-OPEN	SYSTEMS <sup>d</sup>
MATERIAL	Solid pounds <sup>e, f</sup>	Liquid gallons (pounds) <sup>e, f</sup>	Gas (cubic feet at NTP) <sup>e</sup>	Solid pounds <sup>e</sup>	Liquid gallons (pounds) <sup>e</sup>	Gas (cubic feet at NTP) <sup>e</sup>	Solid pounds <sup>e</sup>	Liquid gallons (pounds) <sup>e</sup>
Corrosive	5,000	500	810 <sup>f, g</sup>	5,000	500	810 <sup>f, g</sup>	1,000	100
Highly toxic	10	(10) <sup>i</sup>	20 <sup>h</sup>	10	(10) <sup>i</sup>	20 <sup>h</sup>	3	(3) <sup>i</sup>
Toxic	500	(500) <sup>i</sup>	810 <sup>f</sup>	500	(500) <sup>i</sup>	810 <sup>f</sup>	125	(125) <sup>i</sup>

#### [F] TABLE 307.1(2) MAXIMUM ALLOWABLE QUANTITY PER CONTROL AREA OF HAZARDOUS MATERIAL POSING A HEALTH HAZARD<sup>a, b, c, j</sup>

For SI: 1 cubic foot =  $0.028 \text{ m}^3$ , 1 pound = 0.454 kg, 1 gallon = 3.785 L.

a. For use of control areas, see Section 414.2.

b. In retail and wholesale sales occupancies, the quantities of medicines, foodstuffs, consumer or industrial products, and cosmetics, containing not more than 50 percent by volume of water-miscible liquids and with the remainder of the solutions not being flammable, shall not be limited, provided that such materials are packaged in individual containers not exceeding 1.3 gallons.

c. For storage and display quantities in Group M and storage quantities in Group S occupancies complying with Section 414.2.5, see Tables 414.2.5(1) and 414.2.5(2).

d. The aggregate quantity in use and storage shall not exceed the quantity listed for storage.

e. Quantities shall be increased 100 percent in buildings equipped throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1. Where Note f also applies, the increase for both notes shall be applied accumulatively.

f. Quantities shall be increased 100 percent when stored in approved storage cabinets, gas cabinets or exhausted enclosures as specified in the *Fire Code*. Where Note e also applies, the increase for both notes shall be applied accumulatively.

g. A single cylinder containing 150 pounds or less of anhydrous ammonia in a single control area in a nonsprinklered building shall be considered a maximum allowable quantity. Two cylinders, each containing 150 pounds or less in a single control area, shall be considered a maximum allowable quantity provided the building is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1.

h. Allowed only when stored in approved exhausted gas cabinets or exhausted enclosures as specified in the Fire Code.

i. Quantities in parenthesis indicate quantity units in parenthesis at the head of each column.

j. For gallons of liquids, divide the amount in pounds by 10 in accordance with Section 2703.1.2 of the Fire Code.

**EXPLOSIVE.** Any chemical compound, mixture or device, the primary or common purpose of which is to function by explosion. The term includes, but is not limited to, dynamite, black powder, pellet powder, initiating explosives, detonators, safety fuses, squibs, detonating cord, igniter cord, igniters and display fireworks, 1.3G (Class B, Special).

The term "explosive" includes any material determined to be within the scope of USC Title 18: Chapter 40 and also includes any material classified as an explosive other than consumer fireworks, 1.4G (Class C, Common) by the hazardous materials regulations of DOTn 49 CFR.

**High explosive.** Explosive material, such as dynamite, which can be caused to detonate by means of a No. 8 test blasting cap when unconfined.

**Low explosive.** Explosive material that will burn or deflagrate when ignited. It is characterized by a rate of reaction that is less than the speed of sound. Examples of low explosives include, but are not limited to, black powder; safety fuse; igniters; igniter cord; fuse lighters; fireworks, 1.3G (Class B, Special) and propellants, 1.3C.

**Mass-detonating explosives.** Division 1.1, 1.2 and 1.5 explosives alone or in combination, or loaded into various types of ammunition or containers, most of which can be expected to explode virtually instantaneously when a small portion is subjected to fire, severe concussion, impact, the impulse of an initiating agent or the effect of a considerable discharge of energy from without. Materials that react in this manner represent a mass explosion hazard. Such an explosive will normally cause severe structural damage to adjacent objects. Explosive propagation could occur immediately to other items of ammunition and explosives stored sufficiently close to and not adequately protected from the

initially exploding pile with a time interval short enough so that two or more quantities must be considered as one for quantity-distance purposes.

**UN/DOTn Class 1 explosives.** The former classification system used by DOTn included the terms "high" and "low" explosives as defined herein. The following terms further define explosives under the current system applied by DOTn for all explosive materials defined as hazard Class 1 materials. Compatibility group letters are used in concert with the division to specify further limitations on each division noted (i.e., the letter G identifies the material as a pyrotechnic substance or article containing a pyrotechnic substance and similar materials).

**Division 1.1.** Explosives that have a mass explosion hazard. A mass explosion is one which affects almost the entire load instantaneously.

**Division 1.2.** Explosives that have a projection hazard but not a mass explosion hazard.

**Division 1.3.** Explosives that have a fire hazard and either a minor blast hazard or a minor projection hazard or both, but not a mass explosion hazard.

**Division 1.4.** Explosives that pose a minor explosion hazard. The explosive effects are largely confined to the package and no projection of fragments of appreciable size or range is to be expected. An external fire must not cause virtually instantaneous explosion of almost the entire contents of the package.

**Division 1.5.** Very insensitive explosives. This division is comprised of substances that have a mass explosion hazard, but that are so insensitive there is very little probability of initiation or of transition from burning to detonation under normal conditions of transport.

**Division 1.6.** Extremely insensitive articles which do not have a mass explosion hazard. This division is comprised of articles that contain only extremely insensitive detonating substances and which demonstrate a negligible probability of accidental initiation or propagation.

**FIREWORKS.** Any composition or device for the purpose of producing a visible or audible effect for entertainment purposes by combustion, deflagration or detonation that meets the definition of 1.4G fireworks or 1.3G fireworks as set forth herein.

**FIREWORKS, 1.3G.** (Formerly Class B, Special Fireworks.) Large fireworks devices, which are explosive materials, intended for use in fireworks displays and designed to produce audible or visible effects by combustion, deflagration or detonation. Such 1.3G fireworks include, but are not limited to, firecrackers containing more than 130 milligrams (2 grains) of explosive composition, aerial shells containing more than 40 grams of pyrotechnic composition, and other display pieces which exceed the limits for classification as 1.4G fireworks. Such 1.3G fireworks are also described as fireworks, UN0335 by the DOTn.

**FIREWORKS, 1.4G.** (Formerly Class C, Common Fireworks.) Small fireworks devices containing restricted amounts of pyrotechnic composition designed primarily to produce visible or audible effects by combustion. Such 1.4G fireworks which comply with the construction, chemical composition and labeling regulations of the DOTn for fireworks, UN0336, and the U.S. Consumer Product Safety Commission (CPSC) as set forth in CPSC 16 CFR: Parts 1500 and 1507, are not explosive materials for the purpose of this code.

**FLAMMABLE GAS.** A material that is a gas at  $68^{\circ}F(20^{\circ}C)$  or less at 14.7 pounds per square inch atmosphere (psia) (101 kPa) of pressure [a material that has a boiling point of  $68^{\circ}F(20^{\circ}C)$  or less at 14.7 psia (101 kPa)] which:

- 1. Is ignitable at 14.7 psia (101 kPa) when in a mixture of 13 percent or less by volume with air; or
- 2. Has a flammable range at 14.7 psia (101 kPa) with air of at least 12 percent, regardless of the lower limit.

The limits specified shall be determined at 14.7 psi (101 kPa) of pressure and a temperature of  $68^{\circ}F$  (20°C) in accordance with ASTM E 681.

**FLAMMABLE LIQUEFIED GAS.** A liquefied compressed gas which, under a charged pressure, is partially liquid at a temperature of 68°F (20°C) and which is flammable.

**FLAMMABLE LIQUID.** A liquid having a closed cup flash point below 100°F (38°C). Flammable liquids are further categorized into a group known as Class I liquids. The Class I category is subdivided as follows:

**Class IA.** Liquids having a flash point below  $73^{\circ}F(23^{\circ}C)$  and a boiling point below  $100^{\circ}F(38^{\circ}C)$ .

**Class IB.** Liquids having a flash point below  $73^{\circ}F(23^{\circ}C)$  and a boiling point at or above  $100^{\circ}F(38^{\circ}C)$ .

**Class IC.** Liquids having a flash point at or above  $73^{\circ}$ F (23°C) and below 100°F (38°C).

The category of flammable liquids does not include compressed gases or cryogenic fluids. **FLAMMABLE MATERIAL.** A material capable of being readily ignited from common sources of heat or at a temperature of  $600^{\circ}$ F (316°C) or less.

**FLAMMABLE SOLID.** A solid, other than a blasting agent or explosive, that is capable of causing fire through friction, absorption or moisture, spontaneous chemical change, or retained heat from manufacturing or processing, or which has an ignition temperature below 212°F (100°C) or which burns so vigorously and persistently when ignited as to create a serious hazard. A chemical shall be considered a flammable solid as determined in accordance with the test method of CPSC 16 CFR; Part 1500.44, if it ignites and burns with a self-sustained flame at a rate greater than 0.1 inch (2.5 mm) per second along its major axis.

**FLASH POINT.** The minimum temperature in degrees Fahrenheit at which a liquid will give off sufficient vapors to form an ignitable mixture with air near the surface or in the container, but will not sustain combustion. The flash point of a liquid shall be determined by appropriate test procedure and apparatus as specified in ASTM D 56, ASTM D 93 or ASTM D 3278.

**HANDLING.** The deliberate transport by any means to a point of storage or use.

**HAZARDOUS MATERIALS.** Those chemicals or substances that are physical hazards or health hazards as defined and classified in this section and the *Fire Code*, whether the materials are in usable or waste condition.

**HEALTH HAZARD.** A classification of a chemical for which there is statistically significant evidence that acute or chronic health effects are capable of occurring in exposed persons. The term "health hazard" includes chemicals that are toxic or highly toxic, and corrosive.

**HIGHLY TOXIC.** A material which produces a lethal dose or lethal concentration that falls within any of the following categories:

- 1. A chemical that has a median lethal dose  $(LD_{50})$  of 50 milligrams or less per kilogram of body weight when administered orally to albino rats weighing between 200 and 300 grams each.
- 2. A chemical that has a median lethal dose  $(LD_{50})$  of 200 milligrams or less per kilogram of body weight when administered by continuous contact for 24 hours (or less if death occurs within 24 hours) with the bare skin of albino rabbits weighing between 2 and 3 kilograms each.
- 3. A chemical that has a median lethal concentration  $(LC_{50})$  in air of 200 parts per million by volume or less of gas or vapor, or 2 milligrams per liter or less of mist, fume or dust, when administered by continuous inhalation for 1 hour (or less if death occurs within 1 hour) to albino rats weighing between 200 and 300 grams each.

Mixtures of these materials with ordinary materials, such as water, might not warrant classification as highly toxic. While this system is basically simple in application, any hazard evaluation that is required for the precise categorization of this type of material shall be performed by experienced, technically competent persons. **INCOMPATIBLE MATERIALS.** Materials that, when mixed, have the potential to react in a manner that generates heat, fumes, gases or byproducts which are hazardous to life or property.

**OPEN SYSTEM.** The use of a solid or liquid hazardous material involving a vessel or system that is continuously open to the atmosphere during normal operations and where vapors are liberated, or the product is exposed to the atmosphere during normal operations. Examples of open systems for solids and liquids include dispensing from or into open beakers or containers, dip tank and plating tank operations.

**OPERATING BUILDING.** A building occupied in conjunction with the manufacture, transportation or use of explosive materials. Operating buildings are separated from one another with the use of intraplant or intraline distances.

**ORGANIC PEROXIDE.** An organic compound that contains the bivalent -O-O- structure and which may be considered to be a structural derivative of hydrogen peroxide where one or both of the hydrogen atoms have been replaced by an organic radical. Organic peroxides can pose an explosion hazard (detonation or deflagration) or they can be shock sensitive. They can also decompose into various unstable compounds over an extended period of time.

**Class I.** Those formulations that are capable of deflagration but not detonation.

**Class II.** Those formulations that burn very rapidly and that pose a moderate reactivity hazard.

**Class III.** Those formulations that burn rapidly and that pose a moderate reactivity hazard.

**Class IV.** Those formulations that burn in the same manner as ordinary combustibles and that pose a minimal reactivity hazard.

**Class V.** Those formulations that burn with less intensity than ordinary combustibles or do not sustain combustion and that pose no reactivity hazard.

**Unclassified detonable.** Organic peroxides that are capable of detonation. These peroxides pose an extremely high explosion hazard through rapid explosive decomposition.

**OXIDIZER.** A material that readily yields oxygen or other oxidizing gas, or that readily reacts to promote or initiate combustion of combustible materials. Examples of other oxidizing gases include bromine, chlorine and fluorine.

**Class 4.** An oxidizer that can undergo an explosive reaction due to contamination or exposure to thermal or physical shock. Additionally, the oxidizer will enhance the burning rate and can cause spontaneous ignition of combustibles.

**Class 3.** An oxidizer that will cause a severe increase in the burning rate of combustible materials with which it comes in contact or that will undergo vigorous self-sustained decomposition due to contamination or exposure to heat.

**Class 2.** An oxidizer that will cause a moderate increase in the burning rate or that causes spontaneous ignition of combustible materials with which it comes in contact.

**Class 1.** An oxidizer whose primary hazard is that it slightly increases the burning rate but which does not cause sponta-

neous ignition when it comes in contact with combustible materials.

**OXIDIZING GAS.** A gas that can support and accelerate combustion of other materials.

**PHYSICAL HAZARD.** A chemical for which there is evidence that it is a combustible liquid, compressed gas, cryogenic, explosive, flammable gas, flammable liquid, flammable solid, organic peroxide, oxidizer, pyrophoric or unstable (reactive) or water-reactive material.

**PYROPHORIC.** A chemical with an autoignition temperature in air, at or below a temperature of  $130^{\circ}$ F (54.4°C).

**PYROTECHNIC COMPOSITION.** A chemical mixture that produces visible light displays or sounds through a self-propagating, heat-releasing chemical reaction which is initiated by ignition.

**TOXIC.** A chemical falling within any of the following categories:

- 1. A chemical that has a median lethal dose  $(LD_{50})$  of more than 50 milligrams per kilogram, but not more than 500 milligrams per kilogram of body weight when administered orally to albino rats weighing between 200 and 300 grams each.
- 2. A chemical that has a median lethal dose  $(LD_{50})$  of more than 200 milligrams per kilogram but not more than 1,000 milligrams per kilogram of body weight when administered by continuous contact for 24 hours (or less if death occurs within 24 hours) with the bare skin of albino rabbits weighing between 2 and 3 kilograms each.
- 3. A chemical that has a median lethal concentration ( $LC_{50}$ ) in air of more than 200 parts per million but not more than 2,000 parts per million by volume of gas or vapor, or more than 2 milligrams per liter but not more than 20 milligrams per liter of mist, fume or dust, when administered by continuous inhalation for 1 hour (or less if death occurs within 1 hour) to albino rats weighing between 200 and 300 grams each.

**UNSTABLE (REACTIVE) MATERIAL.** A material, other than an explosive, which in the pure state or as commercially produced, will vigorously polymerize, decompose, condense or become self-reactive and undergo other violent chemical changes, including explosion, when exposed to heat, friction or shock, or in the absence of an inhibitor, or in the presence of contaminants, or in contact with incompatible materials. Unstable (reactive) materials are subdivided as follows:

**Class 4.** Materials that in themselves are readily capable of detonation or explosive decomposition or explosive reaction at normal temperatures and pressures. This class includes materials that are sensitive to mechanical or localized thermal shock at normal temperatures and pressures.

**Class 3.** Materials that in themselves are capable of detonation or of explosive decomposition or explosive reaction but which require a strong initiating source or which must be heated under confinement before initiation. This class includes materials that are sensitive to thermal or mechanical shock at elevated temperatures and pressures. **Class 2.** Materials that in themselves are normally unstable and readily undergo violent chemical change but do not detonate. This class includes materials that can undergo chemical change with rapid release of energy at normal temperatures and pressures, and that can undergo violent chemical change at elevated temperatures and pressures.

**Class 1.** Materials that in themselves are normally stable but which can become unstable at elevated temperatures and pressure.

**WATER-REACTIVE MATERIAL.** A material that explodes; violently reacts; produces flammable, toxic or other hazardous gases; or evolves enough heat to cause autoignition or ignition of combustibles upon exposure to water or moisture. Water-reactive materials are subdivided as follows:

**Class 3.** Materials that react explosively with water without requiring heat or confinement.

**Class 2.** Materials that react violently with water or have the ability to boil water. Materials that produce flammable, toxic or other hazardous gases or evolve enough heat to cause autoignition or ignition of combustibles upon exposure to water or moisture.

**Class 1.** Materials that react with water with some release of energy, but not violently.

**[F] 307.3 High-hazard Group H-1.** Buildings and structures containing materials that pose a detonation hazard shall be classified as Group H-1. Such materials shall include, but not be limited to, the following:

Explosives:

Division 1.1 Division 1.2 Division 1.3

**Exception:** Materials that are used and maintained in a form where either confinement or configuration will not elevate the hazard from a mass fire to mass explosion hazard shall be allowed in H-2 occupancies.

Division 1.4

**Exception:** Articles, including articles packaged for shipment, that are not regulated as an explosive under Bureau of Alcohol, Tobacco and Firearms regulations, or unpackaged articles used in process operations that do not propagate a detonation or deflagration between articles shall be allowed in H-3 occupancies.

Division 1.5 Division 1.6

Organic peroxides, unclassified detonable

Oxidizers, Class 4

Unstable (reactive) materials, Class 3 detonable and Class 4 Detonable pyrophoric materials

**[F] 307.4 High-hazard Group H-2.** Buildings and structures containing materials that pose a deflagration hazard or a hazard from accelerated burning shall be classified as Group H-2. Such materials shall include, but not be limited to, the following:

Class I, II or IIIA flammable or combustible liquids which are used or stored in normally open containers or systems, or in closed containers or systems pressurized at more than 15 psi (103.4 kPa) gage.

Combustible dusts

Cryogenic fluids, flammable

Flammable gases

Organic peroxides, Class I

Oxidizers, Class 3, that are used or stored in normally open containers or systems, or in closed containers or systems pressurized at more than 15 psi (103 kPa) gage

Pyrophoric liquids, solids and gases, nondetonable Unstable (reactive) materials, Class 3, nondetonable Water-reactive materials, Class 3

**[F] 307.5 High-hazard Group H-3.** Buildings and structures containing materials that readily support combustion or that pose a physical hazard shall be classified as Group H-3. Such materials shall include, but not be limited to, the following:

Class I, II or IIIA flammable or combustible liquids that are used or stored in normally closed containers or systems pressurized at 15 pounds per square inch gauge (103.4 kPa) or less Combustible fibers, other than densely packed baled cotton Consumer fireworks, 1.4G (Class C, Common) Cryogenic fluids, oxidizing Flammable solids Organic peroxides, Class II and III Oxidizers, Class 2 Oxidizers, Class 3, that are used or stored in normally closed containers or systems pressurized at 15 pounds per square inch gauge (103 kPa) or less Oxidizing gases Unstable (reactive) materials, Class 2 Water-reactive materials, Class 2

**[F] 307.6 High-hazard Group H-4.** Buildings and structures which contain materials that are health hazards shall be classified as Group H-4. Such materials shall include, but not be limited to, the following:

Corrosives Highly toxic materials Toxic materials

**[F] 307.7 High-hazard Group H-5 structures.** Semiconductor fabrication facilities and comparable research and development areas in which hazardous production materials (HPM) are used and the aggregate quantity of materials is in excess of those listed in Tables 307.1(1) and 307.1(2) shall be classified as Group H-5. Such facilities and areas shall be designed and constructed in accordance with Section 415.8.

**[F] 307.8 Multiple hazards.** Buildings and structures containing a material or materials representing hazards that are classified in one or more of Groups H-1, H-2, H-3 and H-4 shall conform to the code requirements for each of the occupancies so classified.

# SECTION 308 INSTITUTIONAL GROUP I

**308.1 Institutional Group I.** Institutional Group I occupancy includes, among others, the use of a building or structure, or a portion thereof, in which people are cared for or live in a super-

vised environment, having physical limitations because of health or age are harbored for medical treatment, health care, personal care or other care or treatment, or in which people are detained for penal or correctional purposes or in which the liberty of the occupants is restricted. Institutional occupancies shall be classified as Group I-1, I-2, I-3 or I-4.

**308.2 Group I-1.** This occupancy shall include buildings, structures or parts thereof housing more than 16 persons, on a 24-hour basis, who because of age, mental disability or other reasons, live in a supervised residential environment that provides personal care services. The occupants are capable of responding to an emergency situation without physical assis-

tance from staff and are capable of self-preservation. This group shall include, but not be limited to, the following:

Residential board and care facilities Assisted living facilities Halfway houses Group homes

Congregate care residences Social rehabilitation facilities Alcohol and drug centers Convalescent facilities

A facility such as the above with five or fewer persons shall be classified as a Group R-3 or shall comply with the *Residential Code* in accordance with Section 101.2. A facility such as above, housing at least six and not more than 16 persons, shall be classified as Group R-4.

**308.2.1 Residential facility.** A residential facility or portion thereof, subject to licensure by the state, where personal care is administered for more than 16 persons whose occupants may require assisted self-preservation shall be classified as Group SR-1 occupancy and shall comply with Appendix SR.

308.3 Group I-2. This occupancy shall include buildings and structures used for medical, surgical, psychiatric, nursing, health or custodial care for persons who are not capable of self-preservation. This group shall include, but not be limited to, the following:

Hospitals Nursing homes Mental hospitals Detoxification facilities Ambulatory health care facilities

**Note:** The information within this box is not part of the code but is provided for the reader's convenience. Designers and owners of ambulatory health care facilities that are intended to be certified for federal funding shall also meet the standards adopted by the Certification of Medicare and Medicaid Services (CMS), which are regulated and enforced by the Oregon Department of Health Services and the Office of State Fire Marshal. For more information regarding certification requirements, see the Construction Project Guide, which is produced by the Facilities Planning and Safety Unit of the Oregon Department of Health Services.

**Note:** Adult foster homes are not regulated by the requirements of Section 308. See Section 310.

**308.3.1 Child care facility.** A child care facility that provides care on a 24-hour basis to more than five children  $2^{1}/_{2}$  years of age or less shall be classified as Group I-2.

**308.3.2 Definitions.** The following words and terms shall, for the purposes of this section and as used elsewhere in this code, have the meanings shown herein.

**AMBULATORY HEALTH CARE FACILITY.** Ambulatory health care facilities are medical facilities for more than five patients who are incapable of self-preservation providing care on a less than 24-hour basis. (For facilities with five or fewer patients, see Clinic-outpatient in Section 304.1).

**DETOXIFICATION FACILITY.** Detoxification facilities serve patients who are provided treatment for substance abuse on a 24-hour basis and who may be incapable of self-preservation or who may be harmful to others.

**NURSING HOMES.** Nursing homes are long-term care facilities on a 24-hour basis including both intermediate care facilities and skilled nursing facilities, serving more than five persons who may be incapable of self-preservation.

**HOSPITALS AND MENTAL HOSPITALS.** A building or portion thereof used on a 24-hour basis for the medical, psychiatric, obstetrical, or surgical treatment of inpatients who may be incapable of self-preservation.

**308.3.3 Residential facility.** A residential facility or portion thereof, subject to licensure by the state, where personal care is administered for more than five persons, whose occupants may require assisted self-preservation (impractical), shall be classified as a Group SR-2 occupancy and shall comply with Appendix SR.

**308.4 Group I-3.** This occupancy shall include buildings and structures that are inhabited by more than five persons who are under restraint or security. An I-3 facility is occupied by persons who are generally incapable of self-preservation due to security measures not under the occupants' control. This group shall include, but not be limited to, the following:

Prisons Jails Reformatories Detention centers Correctional centers Prerelease centers

Buildings of Group I-3 shall be classified as one of the occupancy conditions indicated in Sections 308.4.1 through 308.4.5 (see Section 408.1).

**308.4.1 Condition 1.** This occupancy condition shall include buildings in which free movement is allowed from sleeping areas, and other spaces where access or occupancy is permitted, to the exterior via means of egress without restraint. A Condition 1 facility is permitted to be constructed as Group R.

**308.4.2 Condition 2.** This occupancy condition shall include buildings in which free movement is allowed from sleeping areas and any other occupied smoke compartment to one or more other smoke compartments. Egress to the exterior is impeded by locked exits.

**308.4.3 Condition 3.** This occupancy condition shall include buildings in which free movement is allowed within

individual smoke compartments, such as within a residential unit comprised of individual sleeping units and group activity spaces, where egress is impeded by remote-controlled release of means of egress from such a smoke compartment to another smoke compartment.

**308.4.4 Condition 4.** This occupancy condition shall include buildings in which free movement is restricted from an occupied space. Remote-controlled release is provided to permit movement from sleeping units, activity spaces and other occupied areas within the smoke compartment to other smoke compartments.

**308.4.5 Condition 5.** This occupancy condition shall include buildings in which free movement is restricted from an occupied space. Staff-controlled manual release is provided to permit movement from sleeping units, activity spaces and other occupied areas within the smoke compartment to other smoke compartments.

**308.5 Group I-4, day care facilities.** This group shall include buildings and structures occupied by persons of any age who receive custodial care for less than 24 hours by individuals other than parents or guardians, relatives by blood, marriage or adoption, and in a place other than the home of the person cared for. A facility such as the above with six or fewer persons or family child care homes (located in a private residence) as defined in Section 310.2, shall be classified as a Group R-3 or shall comply with the *Residential Code* in accordance with Section 101.2. Places of worship during religious functions are not included.

**308.5.1 Adult care facility.** A facility that provides accommodations for less than 24 hours for more than five unrelated adults and provides supervision and personal care services shall be classified as Group I-4.

**Exception:** A facility where occupants are capable of responding to an emergency situation without physical assistance from the staff shall be classified as Group A-3.

**308.5.2 Child care facility.** A facility that provides supervision and personal care on less than a 24-hour basis for more than five children  $2^{1}/_{2}$  years of age or less shall be classified as Group I-4.

**Exception:** A child day care facility that provides care for more than five but no more than 100 children  $2^{1}/_{2}$  years or less of age, when the rooms where such children are cared for are located on the level of exit discharge and each of these child care rooms has an exit door directly to the exterior, shall be classified as Group E.

# SECTION 309 MERCANTILE GROUP M

**309.1 Mercantile Group M.** Mercantile Group M occupancy includes, among others, buildings and structures or a portion thereof, for the display and sale of merchandise, and involves stocks of goods, wares or merchandise incidental to such purposes and accessible to the public. Mercantile occupancies shall include, but not be limited to, the following:

Department stores Drug stores Markets Motor fuel-dispensing facilities Retail or wholesale stores Sales rooms

**309.2 Quantity of hazardous materials.** The aggregate quantity of nonflammable solid and nonflammable or noncombustible liquid hazardous materials stored or displayed in a single control area of a Group M occupancy shall not exceed the quantities in Table 414.2.5(1).

## SECTION 310 RESIDENTIAL GROUP R

**310.1 Residential Group R.** Residential Group R includes, among others, the use of a building or structure, or a portion thereof, for sleeping purposes when not classified as an Institutional Group I or when not regulated by the *Residential Code* in accordance with Section 101.2. Residential occupancies shall include the following:

**R-1** Residential occupancies containing sleeping units where the occupants are primarily transient in nature, including:

Boarding houses (transient) Hotels (transient) Motels (transient)

**R-2** Residential occupancies containing sleeping units or more than two dwelling units where the occupants are primarily permanent in nature, including:

Apartment houses Boarding houses (not transient) Convents Dormitories Fraternities and sororities Hotels (nontransient) Monasteries Motels (nontransient) Vacation timeshare properties

Congregate living facilities with 16 or fewer occupants are permitted to comply with the construction requirements for Group R-3.

Group R-2 occupancies providing 21 or more housing units for low-income elderly, which are financed in whole or in part by the federal or state fund, shall contain a multi-service room adequate in size to seat all the tenants (see ORS 455.425). The multi-service room shall include adjacent toilet facilities for both sexes; a service area with a kitchen sink, countertop and upper and lower cabinets; and a storage room sized to store tables, chairs or benches and janitorial supplies and tools. The multi-service room and accessory rooms shall be accessible to disabled persons (see Chapter 11).

**R-3** Residential occupancies where the occupants are primarily permanent in nature and not classified as Group R-1, R-2, R-4 or I, including:

Buildings that do not contain more than two dwelling l units.

Adult care facilities that provide accommodations for

11

1.1

six or fewer persons of any age for less than 24 hours.

Child care facilities that provide accommodations for six or fewer persons of any age for less than 24 hours.

Congregate living facilities with 16 or fewer persons.

Adult foster homes as defined in ORS Chapter 443, or family child care homes (located in a private residence) as defined in Section 310.2.

Adult foster homes and family child care homes that are within a single-family dwelling are permitted to comply with the *Residential Code* in accordance with Section 101.2.

A Group R-3 residential occupancy, subject to licensure by the state, where personal care is administered for five or fewer persons, whose occupants may require assisted self-preservation shall be classified as a Group SR-3 occupancy and shall comply with the provisions of Appendix SR.

Lodging houses as defined in this section are permitted to comply with the *Residential Code* in accordance with Section 101.2.

**R-4** Residential occupancies shall include buildings arranged for occupancy as residential care/assisted living facilities including more than five but not more than 16 occupants, excluding staff.

Group R-4 occupancies shall meet the requirements for construction as defined for Group R-3, except as otherwise provided for in this code, or shall comply with the *Residential Code*.

A Group R-4 residential occupancy shall include buildings, structures or parts thereof housing more than five, but not more than 16 persons, on a 24-hour basis because of age, mental disability or other reasons, who live in a supervised residential environment that provides personal care.

A Group R-4 residential occupancy, or portion thereof, subject to licensure by the state, where personal care is administered for more than five, but not more than 16 persons, whose occupants may required assisted self-preservation shall be classified as a Group SR-4 occupancy and shall comply with the provisions of Appendix SR.

**310.2 Definitions.** The following words and terms shall, for the purposes of this section and as used elsewhere in this code, have the meanings shown herein.

# Adult foster homes are regulated by ORS 443.705 through 443.725, which are not part of this code but are reproduced in part here for the reader's convenience:

**443.705(1)** "Adult foster home" means any family home or facility in which residential care is provided in a homelike environment for five or fewer adults who are not related to the provider by blood or marriage.

443.725 License required; resident manager required; when other resident staff required.

(1) Every provider of adult foster care shall be licensed with the Department of Human Services before opening or operating an adult foster home caring for adult residents.

(2) A provider must live in the home that is to be licensed or hire a resident manager to live in the home.

(3) There must be a provider, resident manager or substitute caregiver on duty 24 hours per day in an adult foster home under the jurisdiction of the Department of Human Services.

Family child care homes and group child care homes located in a private residence are regulated by ORS 657A.250 and 657A.460, which are not part of this code but are reproduced in part here for the reader's convenience:

**657A.250 Definitions for ORS 657A.030 and 657A.250 to 657A.450.** As used in ORS 657A.030 and 657A.250 to 657A.450, unless the context requires otherwise:

(2) "Certification" means the certification that is issued under ORS 657A.280 by the Child Care Division to a family child care home, child care center or other child care facility.

(3) "Child" means a child under 13 years of age or a child under 18 years of age who has special needs or disabilities and requires a level of care that is above normal for the child's age.

(4) Subject to ORS 657A.440, "child care" mans the care, supervision and guidance on a regular basis of a child unaccompanied by a parent, guardian or custodian, provided to a child during a part of the 24 hours of the day, in a place other than the child's home, with or without compensation.

(5) "Child care facility" means any facility that provides child care to children, including a day nursery, nursery school, child care center, certified or registered family child care home or similar unit operating under any name, but not including any:

(a) Facility providing care that is primarily educational, unless provided to a preschool child for more than four hours a day.

(b) Facility providing care that is primarily supervised training in a specific subject, including but not limited to dancing, drama, music or religion.

(c) Facility providing care that is primarily an incident of group athletic or social activities sponsored by or under the supervision of an organized club or hobby group.

(d) Facility operated by:

(A) A school district as defined in ORS 332.002;

(B) Political subdivision of this state; or

(C) A governmental agency.

(D) Residential facility licensed under ORS 443.400 to 443.455.

(e) Babysitters.

(f) Facility operated as a parent cooperative for no more than four hours a day.

(g) Facility providing care while the child's parent remains on the premises and is engages in an activity offered by the facility or in other nonwork activity.

(10) "Registration" means the registration that is issued under ORS 657A.330 by the Child Care Division to a family child care home where care is provided in the family living quarters of the provider's home.

(11) "School age" means of an age eligible to be enrolled in the first grade or above and, during the months of summer vacation from school, means of an age eligible to be enrolled in first grade or above in the next school year.

# ADULT FOSTER HOME. See ORS 443.705 to 443.725.

**BOARDING HOUSE.** A building arranged or used for lodging for compensation, with or without meals, and not occupied as a single-family unit.

**CONGREGATE LIVING FACILITIES.** A building or part thereof that contains sleeping units where residents share bathroom and/or kitchen facilities.

**DORMITORY.** A space in a building where group sleeping accommodations are provided in one room, or in a series of closely associated rooms, for persons not members of the same family group, under joint occupancy and single management, as in college dormitories or fraternity houses.

**FAMILY CHILD CARE HOME** (Licensed by Oregon Child Care Division under ORS 657A); Includes Certified Family Child Care Homes (located in homes licensed for 16 or fewer children) and Registered Family Child Care Homes (located in homes licensed for 10 or fewer children).

**LODGING HOUSE.** Any building or portion thereof containing not more than five guest rooms where rent is paid in money, goods, labor or otherwise.

PERSONAL CARE. See Appendix SR, Section 102.

**TRANSIENT.** Occupancy of a dwelling unit or sleeping unit for not more than 30 days.

# SECTION 311 STORAGE GROUP S

**311.1 Storage Group S.** Storage Group S occupancy includes, among others, the use of a building or structure, or a portion thereof, for storage that is not classified as a hazardous occupancy.

**311.2 Moderate-hazard storage, Group S-1.** Buildings occupied for storage uses that are not classified as Group S-2, including, but not limited to, storage of the following:

Aerosols, Levels 2 and 3 Aircraft repair hangar Bags: cloth, burlap and paper Bamboos and rattan Baskets Belting: canvas and leather Books and paper in rolls or packs Boots and shoes Buttons, including cloth covered, pearl or bone Cardboard and cardboard boxes Clothing, woolen wearing apparel Cordage Dry boat storage (indoor) Furniture Furs Glues, mucilage, pastes and size Grains Horns and combs, other than celluloid Leather

Linoleum

I

>

Lumber

Motor vehicle repair garages complying with the maximum allowable quantities of hazardous materials listed in Table 307.1(1) (see Section 406.6)

Photo engravings Resilient flooring Silks Soaps Sugar Tires, bulk storage of Tobacco, cigars, cigarettes and snuff Upholstery and mattresses Wax candles

**311.3 Low-hazard storage, Group S-2.** Includes, among others, buildings used for the storage of noncombustible materials such as products on wood pallets or in paper cartons with or without single thickness divisions; or in paper wrappings. Such products are permitted to have a negligible amount of plastic trim, such as knobs, handles or film wrapping. Storage uses shall include, but not be limited to, storage of the following:

Aircraft hangar without major maintenance or overhaul 11 Asbestos Beverages up to and including 16-percent alcohol in wood barrels, metal, glass or ceramic containers Cement in bags Chalk and crayons Dairy products in nonwaxed coated paper containers Dry cell batteries Electrical coils Electrical motors Empty cans Food products Foods in noncombustible containers Fresh fruits and vegetables in nonplastic trays or containers Frozen foods Glass Glass bottles, empty or filled with noncombustible liquids Gypsum board Inert pigments Ivory Meats Metal cabinets Metal desks with plastic tops and trim Metal parts Metals Mirrors Oil-filled and other types of distribution transformers Parking garages, open or enclosed Porcelain and pottery Stoves Talc and soapstones Washers and dryers

**311.4 Mausoleums and columbariums, Group S-3.** The design life of structures in this occupancy are longer than other occupancies in this code. Except where specific provisions are made in Chapter 4, other requirements of this code shall apply.

# SECTION 312 UTILITY AND MISCELLANEOUS GROUP U

**312.1 General.** Buildings and structures of an accessory character and miscellaneous structures not classified in any specific occupancy shall be constructed, equipped and maintained to conform to the requirements of this code commensurate with the fire and life hazard incidental to their occupancy. Group U shall include, but not be limited to, the following:

Non-exempt agricultural buildings (see ORS455.315) Aircraft hangars, accessory to a one- or two-family residence (see Section 412.3) Barns Carports Fences more than 6 feet (1829 mm) high Grain silos, accessory to a residential occupancy Greenhouses Livestock shelters Private garages Retaining walls Sheds Stables Tanks Towers