



WESTERN ANALYTICAL LABORATORY, Inc.
TEST REPORT



REPORT NO: [REDACTED] CLIENT: [REDACTED]
 DATE RECEIVED: August 6, 2020 Philadelphia PA [REDACTED]
 DATE REQUIRED: August 7, 2020 REFERENCE: [REDACTED]

SUBJECT: Polarized Light Microscopy Analysis for Asbestos; 1 sample
 METHODOLOGY: "Method for the Determination of Asbestos in Bulk Building Materials" (EPA 600/R-93/116)
 ACCREDITED: National Institute of Standards and Technology (NVLAP) # 200037

SAMPLE ID NUMBER	SAMPLE LOCATION AND DESCRIPTION	VISUAL DESCRIPTION	ASBESTIFORM MINERALS	OTHER FIBROUS MATERIALS	NON-FIBROUS MATERIALS
01	Basement Drywall	Gray granular/ fibrous Friable	None Detected	Cellulose 1-2% Fiberglass <1%	Granular Minerals Organics Gypsum

t: Trace (>1% = greater than 1%, <1% = less than 1%)

 Optical Microscopist

 Mike Maladzhikyan, Laboratory Director

This report only applies to the sample(s) tested. This report must not be reproduced except in full, unless approved by Western Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Western Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government.