

ERG Environmental, Inc.
101 Aviator's View Drive, Suite B
Alabaster, Alabama 35007
205-664-2535
ergenviro@aol.com

September 8, 2020



SUBJECT: Limited Asbestos Sampling Report - **ERGE Job No. 20-122**

Dear

Attached you will find ERGE's Chain of Custody form along with the analytical results for the sample you delivered to our office. The result is as follows:

HOMOGENEOUS AREA	MATERIAL TYPE & SAMPLE NO.'S	ANALYTICAL RESULTS
H A - 01	Textured (Popcorn) Material Sample No. 01	No Asbestos Detected

The sample was analyzed using Polarized Light Microscopy (PLM), EPA Method 600/R-93/116. As you can see, the sample was determined to contain no asbestos (8% Vermiculite & 92% Non-fibrous).

Only this material listed in this report were sampled as part of this limited sample analysis. Should additional materials be discovered by demolition/renovation work, all work should be stopped prior to disturbing the material and ERG Environmental, Inc. contacted so as to determine the presence of asbestos or other potentially hazardous materials.

If you have questions or need additional information, please advise.

Sincerely,

Lamar Gilliland
President

042021308

24
Hour

ERG Environmental, Inc.

environmental consultants, asbestos assessment, lead assessment, abatement management
101 Aviator's View Drive, Suite B, Alabaster, Alabama 35007 (205) 664-2535

**CHAIN OF CUSTODY / SAMPLING FORM
INDUSTRIAL HYGIENE LABORATORY SUBCONTRACTOR**

SHEET 1 OF 1

PROJECT # [REDACTED] SAMPLE LOT NUMBER : _____

SAMPLING DATE : 09 - 1 - 2020

COLLECTED BY : Others

NAME OF LABORATORY : C A Lab

TYPE OF SAMPLE

___ 25 mm filter Bulk

___ 37 mm filter ___ Silica Gel

___ Char Tube ___ Other

___ Impregent Reagent

ERG NUMBER	SAMPLE DESCRIPTION	ANALYSIS REQUESTED	LABORATORY NUMBER
20-122 - 01	Textured Material	PLM	
			RECEIVED EMSL CHINA HINSON, N.C. 2020 SEP - 2 AM 10:18

SAMPLES RELINQUISHED BY:

NAME : [REDACTED]
AFFIL :

DATE AND TIME : 09 / 1 / 20
SIGNATURE : [Signature]

SAMPLES TRANSPORTED BY:

COMPANY NAME : Fed Ex

CONDITION SHIPPED : Good

DATE AND TIME : 09 / 1 / 20

SAMPLES RECEIVED BY:

NAME : EMSL

AFFILIATION : _____

CONDITION RECEIVED : _____

DATE AND TIME : _____

SIGNATURE : _____

Handwritten signature/initials

***READ TO FIRST POSITIVE SAMPLES IN EACH HOMOGENEOUS AREA, UNLESS, OTHERWISE NOTED.**

14



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-5974
http://www.EMSL.com / cinnasblab@EMSL.com

EMSL Order: 042021308
Customer ID: ERGE50
Customer PO:
Project ID:

Attention: 
Phone: (205) 664-2535
Fax: (205) 664-0648
Received Date: 09/02/2020 10:20 AM
Analysis Date: 09/02/2020
Collected Date: 09/01/2020
Project: 20-122

Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
20-122-01	Textured Material	White Non-Fibrous Homogeneous		8% Vermiculite 92% Non-fibrous (Other)	None Detected
042021308-0001					

Analyst(s)
Olufunke Akintunde (1)


Samantha Rundstrom, Laboratory Manager
or Other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and meet method specifications unless otherwise noted. The above analyses were performed in general compliance with Appendix E to Subpart E of 40 CFR (previously EPA 600/M4-82-020 "Interim Method") but augmented with procedures outlined in the 1993 ("final") version of the method. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. Unless requested by the client, building materials manufactured with multiple layers (i.e. linoleum, wallboard, etc.) are reported as a single sample. Estimation of uncertainty is available on request.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NVLAP Lab Code 101048-0, AIHA-LAP, LLC-IHLAP Lab 100194, NYS ELAP 10872, NJ DEP 03036, PA ID# 68-00367, LA #04127

Initial report from: 09/03/2020 07:37:48