
Click anywhere in this document to return to Furnace Blower Fan Cycling Control Troubleshooting at InspectApedia.com



- 1. INPUT Voltage: 18-30 volts AC, 50/60 Hertz 125 milliamps max.
- 2. OUTPUT 1 HP @ 120 VAC 2 HP @ 240 VAC

Consult factory for additional ratings.

3. TIME DELAY Adjustable ON & OFF 0-4 MIN. Tolerance: ±20%



COMPONENTS 163636b

4. MECHANICAL

Mounting: Surface mount with 2-#6 screws. Package: Molded ABS housing. Circuit: Conformal coated circuit board. Connections: .250" male guick connect terminals.

5. ENVIRONMENTAL

Operating Temperature: -40°F to +175°F. Storage Temperature: -40°F to +185°F Humidity: To 95%rh non-condensing.

6. U.L. FILE #MH-3917 C.S.A. FILE #LR-9275-35

Henry Technologies, Inc. 701 S. Main Street, Chatham, IL 62629 Tel: 217 483 2406 Fax: 217 483 2408 www.henrytech.com or www.a-1components.com