



CLICK ANYWHERE on THIS PAGE to return to MUNN & STEELE VERMICULITE, MICA-FIL, Siscoe Vermiculite Mine at InspectApedia.com

## Pinchin Ltd. Asbestos Laboratory Certificate of Analysis

Client Project Name: [REDACTED]  
 Client Project No.: N/A  
 Prepared For: [REDACTED]

Lab Reference No.: b304275  
 Date Analyzed: November 24, 2023

### BULK SAMPLE ANALYSIS

SAMPLE IDENTIFICATION	SAMPLE DESCRIPTION	% COMPOSITION (VISUAL ESTIMATE)	
		ASBESTOS	OTHER
1 Right of the attic hatch	Homogeneous, blonde, loose particulate, micaceous material.	None Detected	Vermiculite > 75%
Comments:	This sample is consistent in analysis and visual appearance with vermiculite produced in South Africa which is known to not contain naturally occurring asbestos fibres.		
2 Middle of the attic hatch	Homogeneous, blonde, loose particulate, micaceous material.	None Detected	Vermiculite > 75%
Comments:	This sample is consistent in analysis and visual appearance with vermiculite produced in South Africa which is known to not contain naturally occurring asbestos fibres.		
3 Left corner of the attic	Homogeneous, blonde, loose particulate, micaceous material.	None Detected	Vermiculite > 75%
Comments:	This sample is consistent in analysis and visual appearance with vermiculite produced in South Africa which is known to not contain naturally occurring asbestos fibres.		

Reviewed by:

Reporting Analyst:

Digitally signed by  
 Karina Cockburn  
 Date: 2023.11.24  
 11:26:49-05'00'

Digitally signed by  
 Karina Cockburn  
 Date: 2023.11.24  
 11:27:07-05'00'