

NORTH CAROLINA DEPARTMENT OF
ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

SEPTIC/PUMP TANK RISER ASSEMBLY CONDITIONAL APPROVAL

SEPTIC/PUMP TANK RISER ASSEMBLIES CONDITIONAL APPROVAL: SR-14-R2

ISSUED TO: Patrick Mulhall

Polylok, Inc.

60 Capital Drive

Wallingford, CT 06492

(877)765-9565; (203)284-8514 (Fax); www.polylok.com

FOR: 20-inch and 24-inch Septic Tank and 24-inch Pump Tank Riser Assembly

DATE: August 24, 2001

January 22, 2003 (addition of 24-inch Riser)

February 2, 2004 (addition of Pump tank Riser and Riser Safety Pan)

In accordance with North Carolina General Statute 130A-335, 130A-335.1, and 15A NCAC 18A .1954, an application by Patrick Mulhall of Polylok, Inc. for a modified approval of its riser assembly products has been reviewed. These products have been found to meet the minimum requirements established by statute and rule, when the following conditions for use, installation, operation and maintenance are met, as follows:

I. Description:

- a. Riser assemblies and associated accessories shall be designed and manufactured in accordance with plans, specifications and supporting documents provided by the manufacturer in their application for approval submitted to the On-Site Wastewater Section. The On-Site Wastewater Section shall be notified in writing of any new assemblies or modifications to the approved riser assembly and accessories prior to use in septic tank systems.
- b. Conditionally approved riser assemblies and other accessories shall meet the specifications outlined in Table 1:

Table 1. Conditionally Approved Riser Model Specifications (Polylok, Inc.)			
Riser Models	Inside dia.	Min. Tank Top Width Required	Installation Limitations ^{1,2}
20" HDPE Round Riser (6" high stackable sections) and Lid Assembly with Tamper-Resistant Stainless Steel Screws and 7-inch Riser Safety Pan ³ and internal concrete plug	20"	28"	Septic Tank must be installed 6" below finished grade or at least 3" above finished grade.
24" HDPE Round Riser (6" high stackable sections) and Lid Assembly with Tamper-Resistant Stainless Steel Screws with internal concrete plug	24"	32"	Septic Tank must be installed 6" below finished grade or at least 3" above finished grade. Pump Tank ⁴ : Must be installed at least 6 " above finished grade.

Notes:

1. These riser systems must not be subjected to vehicular or other excessive live loads, or buried deeper than three feet below finished grade.
2. Mechanisms to prevent accidental entry to the tank include use of tamper-resistant screws (No. 10 x 1-1/2" square notched head, or approved equal), at least two horizontal safety screws, and internal concrete plug.
3. Riser Safety Pan to be used exclusively with 20-inch septic tank riser to provide support for internal concrete plug. Pans are 7-inches high, with internal diameter of 17 inches. Tank manufacturer is to construct concrete plug to indicated "fill" line on inside of Riser Safety Pan poured to weigh 59 pounds.
4. Top riser section of Pump Tank to have concrete safety plug (minimum 2.5 inches thick) constructed by tank manufacture in special octagonal Polylok Riser Safety Form provided by the riser manufacturer which shall sit securely on the internal horizontal rib of the riser. Lower pump tank riser sections shall include pre-formed bosses and bulkhead fittings or grommets provided by the riser manufacturer through which wire conduit and pump discharge pipe can be installed.

II. Use:

A tank manufacturer may propose to use these conditionally approved riser assemblies in one or more of their septic tanks or pump tanks. The tank manufacturer must notify the On-Site Wastewater Section in accordance with Rule .1953 of the tanks in which they propose to utilize these conditionally approved risers, showing any modifications to the approved tank plans which may be necessary to utilize the proposed risers.

III. Installation:

- A. The riser assemblies shall be assembled and installed in accordance with the manufacturer's specifications, applicable rules and approval conditions.

Septic Tank Installations: For new installations (for systems constructed on or after January 1, 1999), a Polylok riser section or riser safety pan (20-inch risers only) shall be cast into the tank during tank construction. One of the following installation methods shall be used:

- i) Cast-in-place with internal collar: The bottom riser section shall be cast in the concrete (with the riser lid secured in place), retaining a concrete inner collar around the internal circumference of the riser (to form at least a 17-inch diameter or 21-inch opening, for the 20-inch and 24-inch models, respectively). The riser shall be placed in the tank top mold in such a manner that 1-½ inches of concrete shall be cast below the riser bottom. A tapered concrete support collar shall surround the riser beginning at a height of at least four-inches above the bottom of the riser tapering away from the riser on a projected slope of 1:8. Four No. 3 rebars (one each on every side of the riser, making a picture frame) shall be placed one inch away extending three to six inches beyond the riser; or
- ii) Cast-in-place with Riser Safety Pan (option for 20-inch riser only): Riser Safety Pan section shall be cast into the top of the tank, anchored to the mold using 4 plastic mold nails provided by the riser manufacturer, or alternately held to mold with pre-manufactured concrete plug in place. Concrete plug is to be constructed to specified thickness and weight (59 pounds). When tank top slab is less than four inches thick, a concrete fillet shall be provided around the riser so that the total thickness of concrete slab will be at least four inches around the riser, tapering away from the riser on a projected slope of 1:8. Four No. 3 rebars (one each on every side of the riser, making a picture frame) shall be placed one inch away extending three to six inches beyond the riser.

Pump Tank Installations:

- i) A 24-inch Polylok riser section (6-inches high) shall be cast directly into the tank fully penetrating the tank top. **Do not remove the external riser flange for the section to be cast into the tank top.** When the tank top slab is less than four inches thick, a concrete fillet shall be provided around the riser so that the total thickness of the concrete slab will be at least four inches around the riser, tapering away from the riser on a projected slope of 1:8. Four No. 3 rebar (one each on every side of opening, making a picture frame) shall be placed one inch away from the opening extending three to six inches beyond the tank opening.
- ii) The top (highest) riser section **shall support a specially constructed internal concrete plug, constructed utilizing Polylok Riser Safety Form provided to the tank manufacturer by Polylok, Inc.** The concrete tank safety plug shall be a minimum 2.5 inches thick and be removable to facilitate service access to the pump, floats or filters.

- iii) Wire connections and the pump discharge pipe shall be made through bulkhead connectors or grommets provided by the riser manufacturer and installed through holes(s) drilled by the installer into smooth portions in the risers midway between two ribs per manufacturer's recommendations, to make a secure watertight connection. For systems where the discharge pipe is designed to pass through the riser, make certain the pump disconnect is reachable from the top of the riser (12-18 inches, maximum, below riser lid), and the pipe shall remain below the local frost line (12-18 inches, minimum, in most of North Carolina).
- B. Riser retrofit installations may be approved by the local health department on a case-by-case basis when used with an existing septic tank. Risers shall be attached in a structurally sound, watertight fashion in accordance with the riser manufacturer's specifications.
- C. Multiple Riser sections must be sealed together with vinyl nitrile gasket to be provided by the riser manufacturer, and secured with six number 10 x 1-1/4 inch stainless steel sheet metal screws provided by the riser manufacturer.
- D. The riser lid shall have a watertight gasket and be screwed down with at least six tamper-resistant stainless steel screws, with gasket and screws as provided by the riser manufacturer. At least two horizontal safety screws shall be provided and located as indicated on top of the riser lid.
- F. For additional security, an internal concrete lid with handle, weighing at least 50 pounds, shall be provided by the tank manufacturer, to be placed on the internal concrete lid or riser safety pan (septic tanks) or on the inner lip of the top riser section (pump tank), as described in detail above.
- G. This riser system must not be installed in areas subjected to vehicular traffic, or where the tank shall be buried more than three feet below finished grade.

IV. Literature:

The riser assembly manufacturer shall furnish with each riser assembly (and/or with associated riser assembly components) all pertinent installation and maintenance details.

V. Maintaining approval status: The approval status is governed by Rule .1954(e).

Approved by:_____Date:_____