



# MONTGOMERY COUNTY HEALTH DEPARTMENT

**Norristown Health Center**  
1430 DeKalb Street, PO Box 311  
Norristown, PA 19404-0311  
610-278-5117  
Fax: 610-278-5167

**Pottstown Health Center**  
364 King Street  
Pottstown, PA 19464  
610-970-5040  
Fax: 610-970-5048

**Eastern Court House Annex**  
102 York Road, Suite 401  
Willow Grove, PA 19090  
215-784-5415  
Fax: 215-784-5524

## INDIVIDUAL WATER ISOLATION DISTANCES

Minimum isolation distances shall be maintained from the individual water supply, irrigation well and open-loop geothermal well to the facilities listed below. Closed-loop geothermal well installations require one half the isolation distances listed below at a minimum.

	<u>SOURCE OF POLLUTION</u>	<u>MINIMUM DISTANCE</u>
1.	Delineated wetlands or floodplains.	25 feet
2.	Lakes, ponds, streams or other surface waters.	25 feet
3.	Storm drains, retention basins, storm water stabilization ponds, rainwater pits.	25 feet
4.	Community spray irrigation site: sewage sludge and septage disposal sites.	100 feet
5.	Farm silos, barnyards, manure pits or tanks or other storage areas of animal manure.	200 feet
6.	Subsurface sewage absorption areas, elevated sand mounds, cesspools, sewage seepage pits, single family spray irrigation system, etc.	100 feet
7.	Septic tanks, aerobic tanks, sewage pump tanks, holding tanks.	50 feet
8.	Gravity sewer lines and drains carrying domestic sewage or industrial waste (unless item 9 applies).	50 feet
9.	Gravity sewer lines and drains using cast iron pipe with watertight lead caulked or neoprene gasketed joints, or Schedule 40 polyvinylchloride (PVC) pipe with solvent welded joints.	10 feet
10.	Sewer lines and drains carrying domestic sewage or industrial waste under pressure (except welded steel pipe or concrete encased pipe).	50 feet
11.	Commercial preparation area or storage area of hazardous spray materials, fertilizers or chemicals; salt piles.	300 feet
12.	Other potential sources of pollution as determined by MCHD.	As approved

CLICK ANYWHERE ON THIS PAGE TO RETURN TO WELL CLEARANCE DISTANCES INFORMATION at [InspectApedia.com](http://InspectApedia.com)

Any proposed deviation or modification from the above isolation distances must be submitted in writing to MCHD stating reasons for such deviation or modification. Upon review of the material, a waiver may be granted. Additional conditions may be required prior to permit issuance.